



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Adrian Leader

Final report

Report no: 20/0605
Date received: 9/04/2020
Testing commenced: 9/04/2020
Date reported: 23/04/2020
No. of samples: 3
Revision no: 00

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 240848

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	20/0605/1 Casino Walker Street 8/04/2020 11:55	20/0605/2 Casino North Res 8/04/2020 12:15	20/0605/3 Casino Sheppard St 8/04/2020 13:00
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.036	0.055	0.39
Copper (Total)	mg/L	APHA3120B	0.005	0.045	0.006	<0.005
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.03	0.16
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.012	0.11
Zinc (Total)	mg/L	APHA3120B	0.005	0.006	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	92	97	103



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 20/0605

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser