



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Sandeep Chugh

Sampled by: AL

* **Subcontract Laboratory:** NSW Health Pathology

* **Subcontract Reference:** 377906912

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Consumer Weekly

Report no: 20/0698

Date received: 29/04/2020

Testing commenced: 29/04/2020

Date reported: 5/05/2020

No. of samples: 9

Revision no: 00

Sample No.: Sample description:	Unit	Method	LOR	20/0698/1 Casino Council Depot 29/04/2020 12:35	20/0698/2 Casino Bruton St 29/04/2020 12:00	20/0698/3 Casino Walker Street 29/04/2020 11:45	20/0698/4 Coraki Memorial Park 30/04/2020 12:57	20/0698/5 Woodburn Riverside Park 30/04/2020 09:09	20/0698/6 Broadwater Community Centre 30/04/2020 10:52	20/0698/7 Rileys Hill Community Centre 30/04/2020 11:07	20/0698/8 Evans Head School 30/04/2020 09:40
pH - field	pH	APHA4500H	2	7.7	7.6	7.6	7.7	8.3	8.4	8.3	8.4
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.52	0.49	0.89	0.36	0.32	0.53	0.46	0.52
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.91	1.00	1.07	0.69	0.52	0.76	0.67	0.85
Temperature - field	Deg. C	APHA2550B	0.1	24.5	23.3	24.3	25.3	24.1	23.7	23.6	24.3
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.3	8.4	8.3	7.7	8.1	8.3	8.2	8.1
Turbidity - field#	NTU	APHA2130B	0.1	0.42	0.40	0.37	0.38	0.26	0.32	0.29	0.27
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	6	48	9	3	44	1	<1	15



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 20/0698

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	20/0698/9 Evans Head High Zone 30/04/2020 10:17
pH - field	pH	APHA4500H	2	8.4
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.54
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.76
Temperature - field	Deg.C	APHA2550B	0.1	23.2
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.8
Turbidity - field#	NTU	APHA2130B	0.1	0.34
Total Coliforms*#	MPN/100mL	PNWI01	1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	90

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser