



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Sandeep Chugh  
**Sampled by:** Malcolm Window

Final report

**Report no:** 20/0868  
**Date received:** 3/06/2020  
**Testing commenced:** 3/06/2020  
**Date reported:** 16/06/2020  
**No. of samples:** 3  
**Revision no:** 00

\* **Subcontract Laboratory:** Envirolab (NATA2901)

\* **Subcontract Reference:** 244297

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	20/0868/1 Casino Walker Street 3/06/2020 13:00	20/0868/2 Casino North Res 3/06/2020 13:30	20/0868/3 Casino Sheppard St 3/06/2020 13:20
Colour (True)	Pt-Co	RWL10.02	2	3	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	<0.01	<0.01	<0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	<0.05	<0.05	<0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.028	0.052	0.028
Copper (Total)	mg/L	APHA3120B	0.005	0.007	<0.005	0.01
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.005	0.03
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	0.012
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	48	50	66



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 20/0868

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.  
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'  
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

M Window  
Laboratory Analyst  
Approved Authoriser