



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Gary Mead
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 245300

Final report

Report no: 20/0949
Date received: 17/06/2020
Testing commenced: 17/06/2020
Date reported: 26/06/2020
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	Method	LOR	20/0949-1 RVC Finished Water 17/06/2020 11:30	20/0949-2 RVC Raw Water 17/06/2020 10:45
pH	pH	APHA4500H		7.5	7.8
Electrical Conductivity	µS/cm	APHA2510B	1	364	312
Total Dissolved Solids by calc	mg/L	APHA1030E	2	233	200
Dissolved Oxygen	mg/L	APHA4500OG	0.2	9.7	9.8
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.98	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	26
Colour (True)	Pt-Co	RWL10.02	2	<2	12
Turbidity	NTU	APHA2130B	0.1	<0.10	5.0
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	112	116
Suspended Solids	mg/L	APHA2540D	1	<1	5
Total Organic Carbon*	mg/L	Envirolab	1	2	2
Aluminium (Total)	mg/L	APHA3120B	0.005	0.052	0.31
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.052	0.016



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 20/0949

Sample No.: Sample description:	Unit	Method	LOR	20/0949-1 RVC Finished Water 17/06/2020 11:30	20/0949-2 RVC Raw Water 17/06/2020 10:45
Date sampled:					
Time sampled:					
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.34
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.009
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.049
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.017
Calcium	mg/L	APHA3120B	0.1	23.3	23.5
Magnesium	mg/L	APHA3120B	0.1	13.9	14.0
Hardness as CaCO ₃	mg/L	APHA2340B	1	115	116
Total Coliforms	MPN/100mL	APHA9223B	1	<1	1,602
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	66
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	300

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser