



# Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Sandeep Chugh  
**Sampled by:** Michael MacRae

**Report no:** 20/1460 01  
**Date received:** 25/09/2020  
**Testing commenced:** 25/09/2020  
**Date reported:** 25/09/2020  
**No. samples:** 1

**Sample ID.** WTP Fluoride dosing

**Sample No.** 1

*Analysis results apply to samples as received.*

PARAMETER	Method No.	LOR	Unit	Result
24/09/2020 15:00				
Fluoride - ISE	APHA4500FC	0.05	mg/L	1.10

Final report

Notes: < denotes less than; > denotes greater than; ND denotes 'not detected'

This report must not be reproduced except in full  
This report relates only to the items tested as specified herein  
Samples analysed between date received and date reported

Accredited for compliance with ISO/IEC 17025 - Testing  
The results of the tests, calibrations and/or measurements included in  
this document are traceable to Australian/national standards

# denotes tests that are not covered under the scope of accreditation  
\* denotes tests that are subcontracted  
LOR denotes 'Limit of Reporting'

M Window  
Laboratory Analyst  
Approved Authoriser