



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Micheal MacRae
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 252676

Final report

Report no: 20/1489
Date received: 30/09/2020
Testing commenced: 30/09/2020
Date reported: 15/10/2020
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	20/1489-1 RVC Finished Water 30/09/2020 12:05	20/1489-2 RVC Raw Water 30/09/2020 10:30
pH	pH	APHA4500H		7.5	7.8
Electrical Conductivity	µS/cm	APHA2510B	1	310	279
Total Dissolved Solids by calc	mg/L	APHA1030E	2	198	179
Dissolved Oxygen	mg/L	APHA4500OG	0.2	10.6	10.5
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.082	[NA]
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	51
Colour (True)	Pt-Co	RWL10.02	2	<2	14
Turbidity	NTU	APHA2130B	0.1	<0.10	4.8
Aluminium (Total)	mg/L	APHA3120B	0.005	0.042	0.24
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.041	0.006
Iron (Total)	mg/L	APHA3120B	0.005	<0.005	0.29
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	0.084



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 20/1489

Sample No.: Sample description:	Unit	Method	LOR	20/1489-1 RVC Finished Water 30/09/2020 12:05	20/1489-2 RVC Raw Water 30/09/2020 10:30
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.008
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	97	104
Suspended Solids	mg/L	APHA2540D	1	<1	7
Total Organic Carbon*	mg/L	Envirolab	1	2	3
Calcium	mg/L	APHA3120B	0.1	21.0	20.6
Magnesium	mg/L	APHA3120B	0.1	12.1	11.9
Hardness as CaCO ₃	mg/L	APHA2340B	1	102	100
Total Coliforms	MPN/100mL	APHA9223B	1	<1	1,658
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	11
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	1,830

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

M Window
Laboratory Analyst
Approved Authoriser