



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Sandeep Chugh

Sampled by: Chantel Cremen

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 258135

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Casino Consumer Monthly

Report no: 20/1870

Date received: 9/12/2020

Testing commenced: 9/12/2020

Date reported: 22/12/2020

No. of samples: 3

Revision no: 00

| Sample No.: Sample description: Date sampled: Time sampled: | Unit | Method | LOR | 20/1870/1 Casino Walker Street 9/12/2020 | 20/1870/2 Casino Bruton St 9/12/2020 | 20/1870/3 Casino Council Depot 9/12/2020 |
|--|-------|-----------|-------|--|---|--|
| Colour (True) | Pt-Co | RWL10.02 | 2 | <2 | <2 | <2 |
| Ammonia-N | mg/L | RWL 10.06 | 0.01 | <0.01 | 0.03 | <0.01 |
| Nitrogen - Nitrate-N | mg/L | RWL 10.05 | 0.05 | <0.05 | 0.05 | <0.05 |
| Nitrogen - Nitrite-N | mg/L | RWL 10.05 | 0.01 | <0.01 | <0.01 | <0.01 |
| Aluminium (Total) | mg/L | APHA3120B | 0.005 | 0.058 | 0.050 | 0.059 |
| Copper (Total) | mg/L | APHA3120B | 0.005 | 0.026 | 0.016 | 0.036 |
| Iron (Total) | mg/L | APHA3120B | 0.005 | 0.008 | 0.009 | 0.02 |
| Lead (Total) | mg/L | APHA3120B | 0.005 | <0.005 | <0.005 | <0.005 |
| Manganese (Total) | mg/L | APHA3120B | 0.005 | 0.069 | 0.043 | 0.043 |
| Zinc (Total) | mg/L | APHA3120B | 0.005 | 0.007 | 0.01 | <0.005 |
| Total Trihalomethanes* | µg/L | Envirolab | 1 | 78 | 77 | 76 |



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 20/1870

End of results

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser