



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Adrian Leader
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 256253

Final report

Report no: 20/1764
Date received: 18/11/2020
Testing commenced: 18/11/2020
Date reported: 30/11/2020
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	20/1764-1 RVC Finished Water 17/11/2020	20/1764-2 RVC Raw Water 17/11/2020
pH	pH	APHA4500H		7.6	7.7
Electrical Conductivity	µS/cm	APHA2510B	1	430	340
Total Dissolved Solids by calc	mg/L	APHA1030E	2	275	218
Dissolved Oxygen	mg/L	APHA4500OG	0.2	8.8	7.4
Colour (Apparent)	Pt-Co	RWL10.02	2	<2	74
Colour (True)	Pt-Co	RWL10.02	2	<2	18
Turbidity	NTU	APHA2130B	0.1	0.14	5.1
Aluminium (Total)	mg/L	APHA3120B	0.005	0.049	0.077
Aluminium (Dissolved)	mg/L	APHA3120B	0.005	0.045	<0.005
Iron (Total)	mg/L	APHA3120B	0.005	0.005	0.30
Iron (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.011
Manganese (Total)	mg/L	APHA3120B	0.005	0.01	0.22
Manganese (Dissolved)	mg/L	APHA3120B	0.005	<0.005	0.097



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 20/1764

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	20/1764-1 RVC Finished Water 17/11/2020	20/1764-2 RVC Raw Water 17/11/2020
Alkalinity (as CaCO ₃)	mg/L	APHA2320B	20	124	127
Suspended Solids	mg/L	APHA2540D	1	1	7
Total Organic Carbon*	mg/L	Envirolab	1	2	3
Calcium	mg/L	APHA3120B	0.1	25.5	26.5
Magnesium	mg/L	APHA3120B	0.1	14.8	15.2
Hardness as CaCO ₃	mg/L	APHA2340B	1	125	129
Total Coliforms	MPN/100mL	APHA9223B	1	<1	2,187
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	7
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	1,710

End of results

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
 Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
 # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
 LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
 The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

V. Barnett
Laboratory Analyst
Approved Authoriser