



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Chantel Cremen
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 261683

Final report

Report no: 21/0195
Date received: 10/02/2021
Testing commenced: 10/02/2021
Date reported: 23/02/2021
No. of samples: 2
Revision no: 01

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description: Date sampled: Time sampled:	Unit	LOR	21/0195-1 RVC Finished Water 10/02/2021	21/0195-2 RVC Raw Water 10/02/2021
pH	pH		7.6	7.7
Electrical Conductivity	µS/cm	1	415	258
Total Dissolved Solids by calc	mg/L	2	266	165
Fluoride - ISE	mg/L	0.05	1.03	0.11
Colour (Apparent)	Pt-Co	2	<2	97
Colour (True)	Pt-Co	2	<2	25
Turbidity	NTU	0.1	0.11	9.1
Aluminium (Total)	mg/L	0.005	0.032	0.33
Aluminium (Dissolved)	mg/L	0.005	0.032	<0.005
Iron (Total)	mg/L	0.005	<0.005	0.61
Iron (Dissolved)	mg/L	0.005	<0.005	0.017
Manganese (Total)	mg/L	0.005	<0.005	0.069
Manganese (Dissolved)	mg/L	0.005	<0.005	<0.005



Certificate Of Analysis

Client: Richmond Valley Council


Report no: 21/0195

Sample No.: Sample description: Date sampled: Time sampled:	Unit	LOR	21/0195-1 RVC Finished Water 10/02/2021	21/0195-2 RVC Raw Water 10/02/2021
Alkalinity (as CaCO ₃)	mg/L	20	130	93
Total Organic Carbon*	mg/L	1	2	3
Calcium	mg/L	0.1	17.7	17.0
Magnesium	mg/L	0.1	10.2	9.8
Hardness as CaCO ₃	mg/L	1	86	83
Suspended Solids	mg/L	1	1	17
Total Coliforms	MPN/100mL	1	<1	1,565
<i>E.coli</i>	MPN/100mL	1	<1	58
Heterotrophic Plate Count	MPN/mL	2	<2	1,160

End of results

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
 Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
 # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
 LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
 The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:


 M Window
 Laboratory Analyst
 Approved Authoriser