



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Sandeep Chugh

Sampled by: Chantel Cremen

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 263518

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Casino Consumer Monthly

Report no: 21/0318

Date received: 3/03/2021

Testing commenced: 3/03/2021

Date reported: 15/03/2021

No. of samples: 3

Revision no: 00

| Sample No.: Sample description: | Unit | Method | LOR | 21/0318/1 Casino Walker Street 3/03/2021 13:20 | 21/0318/2 Casino Bruton St 3/03/2021 13:43 | 21/0318/3 Casino Council Depot 3/03/2021 14:17 |
|------------------------------------|-------|------------|-------|---|--|---|
| Date sampled: | | | | | | |
| Time sampled: | | | | | | |
| Fluoride - ISE | mg/L | APHA4500FC | 0.05 | 0.98 | 1.00 | 0.95 |
| Colour (True) | Pt-Co | RWL10.02 | 2 | 2 | <2 | 3 |
| Ammonia-N | mg/L | RWL 10.06 | 0.01 | <0.01 | <0.01 | <0.01 |
| Nitrogen - Nitrate-N | mg/L | RWL 10.05 | 0.05 | 0.21 | 0.21 | 0.19 |
| Nitrogen - Nitrite-N | mg/L | RWL 10.05 | 0.01 | <0.01 | <0.01 | <0.01 |
| Aluminium (Total) | mg/L | APHA3120B | 0.005 | 0.032 | 0.034 | 0.037 |
| Copper (Total) | mg/L | APHA3120B | 0.005 | 0.032 | 0.01 | 0.068 |
| Iron (Total) | mg/L | APHA3120B | 0.005 | 0.006 | 0.01 | 0.03 |
| Lead (Total) | mg/L | APHA3120B | 0.005 | <0.005 | <0.005 | 0.006 |
| Manganese (Total) | mg/L | APHA3120B | 0.005 | 0.006 | 0.008 | 0.007 |
| Zinc (Total) | mg/L | APHA3120B | 0.005 | 0.005 | 0.01 | 0.007 |
| Total Trihalomethanes* | µg/L | Envirolab | 1 | 95 | 90 | 102 |



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 21/0318

End of results

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser