



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Chantel Cremen

Final report

Report no: 21/0521
Date received: 15/04/2021
Testing commenced: 15/04/2021
Date reported: 30/04/2021
No. of samples: 3
Revision no: 00

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 267156

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	21/0521/1 Casino Walker Street 15/04/2021 13:12	21/0521/2 Casino Showground 15/04/2021 12:40	21/0521/3 Casino South Res 15/04/2021 12:55
Fluoride - ISE	mg/L	APHA4500FC	0.05	1.05	0.97	0.999
Colour (True)	Pt-Co	RWL10.02	2	<2	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	0.04	0.03	0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.23	0.22	0.22
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.084	0.085	0.060
Copper (Total)	mg/L	APHA3120B	0.005	0.031	0.01	<0.005
Iron (Total)	mg/L	APHA3120B	0.005	0.02	0.03	0.01
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	0.005	0.036	0.006
Zinc (Total)	mg/L	APHA3120B	0.005	0.009	0.005	<0.005
Total Trihalomethanes*	µg/L	Envirolab	1	79	135	90



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 21/0521

End of results

General comments:

This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser