



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: M. Hodges
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 15227

Final report

Report no: 21/0458
Date received: 31/03/2021
Testing commenced: 31/03/2021
Date reported: 15/04/2021
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	LOR	21/0458-1 RVC Finished Water 31/03/2021 12:55	21/0458-2 RVC Raw Water 31/03/2021 10:05
Date sampled:				
Time sampled:				
pH	pH		7.7	7.6
Electrical Conductivity	µS/cm	1	425	212
Total Dissolved Solids by calc	mg/L	2	272	136
Fluoride - ISE	mg/L	0.05	1.11	[NA]
Colour (Apparent)	Pt-Co	2	<2	290
Colour (True)	Pt-Co	2	<2	49
Turbidity	NTU	0.1	<0.10	36
Aluminium (Total)	mg/L	0.005	0.032	3.54
Aluminium (Dissolved)	mg/L	0.005	0.030	0.006
Iron (Total)	mg/L	0.005	<0.005	3.9
Iron (Dissolved)	mg/L	0.005	<0.005	0.11
Manganese (Total)	mg/L	0.005	<0.005	0.063
Manganese (Dissolved)	mg/L	0.005	<0.005	<0.005



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 21/0458

Sample No.: Sample description:	Unit	LOR	21/0458-1 RVC Finished Water 31/03/2021 12:55	21/0458-2 RVC Raw Water 31/03/2021 10:05
Date sampled:				
Time sampled:				
Alkalinity (as CaCO ₃)	mg/L	20	110	73
Total Organic Carbon*	mg/L	1	2	6
Calcium	mg/L	0.1	15.0	16.1
Magnesium	mg/L	0.1	8.7	9.5
Hardness as CaCO ₃	mg/L	1	73	79
Suspended Solids	mg/L	1	1	42
Total Coliforms	MPN/100mL	1	<1	13,740
<i>E.coli</i>	MPN/100mL	1	<1	192

End of results

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

A. Hawthorne
Laboratory Manager
Approved Authoriser