



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Peter Mills

Final report

Report no: 21/0668 00
Date received: 13/05/2021
Testing commenced: 13/05/2021
Date reported: 26/05/2021
No. of samples: 3

Sampled in accordance with RWL 2.0 to 2.05


Weekly Fluoride & Metals

Sample No.: Sample description:	Unit	Method	LOR	21/0668/1 Casino Walker Street 13/05/2021	21/0668/2 Casino Showground 13/05/2021	21/0668/3 Casino South Res 13/05/2021
Fluoride - ISE	mg/L	APHA4500FC	0.05	0.991	0.99	0.995
Iron (Total)	mg/L	APHA3120B	0.005	0.008	0.006	0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005

End of results

General comments: This report must not be reproduced except in full. This report relates only to the items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected' The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:


M Window
Laboratory Analyst
Approved Authoriser