



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Chantel Cremen

Final report

Report no: 21/0795
Date received: 9/06/2021
Testing commenced: 9/06/2021
Date reported: 22/06/2021
No. of samples: 3
Revision no: 00

* **Subcontract Laboratory:** Envirolab (NATA2901)

* **Subcontract Reference:** 271490

RVC Casino Consumer Monthly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	21/0795/1 Casino Showground	21/0795/2 Casino South Res	21/0795/3 Casino Walker Street
Date sampled: Time sampled:				9/06/2021 11:23	9/06/2021 11:40	9/06/2021 13:21
Colour (True)	Pt-Co	RWL10.02	2	3	<2	<2
Ammonia-N	mg/L	RWL 10.06	0.01	0.01	<0.01	0.01
Nitrogen - Nitrate-N	mg/L	RWL 10.05	0.05	0.09	0.09	0.05
Nitrogen - Nitrite-N	mg/L	RWL 10.05	0.01	<0.01	<0.01	<0.01
Aluminium (Total)	mg/L	APHA3120B	0.005	0.058	0.14	0.15
Copper (Total)	mg/L	APHA3120B	0.005	0.006	<0.005	0.034
Iron (Total)	mg/L	APHA3120B	0.005	0.01	0.02	0.03
Lead (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	<0.005
Manganese (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	0.007
Zinc (Total)	mg/L	APHA3120B	0.005	<0.005	<0.005	0.005
Total Trihalomethanes*	µg/L	Envirolab	1	87	82	58



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 21/0795

End of results

General comments:

This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

M Window
Laboratory Analyst
Approved Authoriser