



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Client
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 271490

Final report

Report no: 21/0800
Date received: 9/06/2021
Testing commenced: 9/06/2021
Date reported: 24/06/2021
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description: Date sampled: Time sampled:	Unit	LOR	21/0800-1 RVC Finished Water 9/06/2021	21/0800-2 RVC Raw Water 9/06/2021
Alkalinity (as CaCO ₃)	mg/L	20	117	121
Aluminium (Dissolved)	mg/L	0.005	0.048	<0.005
Aluminium (Total)	mg/L	0.005	0.073	0.27
Calcium	mg/L	0.1	24.6	24.2
Colour (Apparent)	Pt-Co	2	<2	54
Colour (True)	Pt-Co	2	<2	15
<i>E. coli</i>	MPN/100mL	1	<1	83
Electrical Conductivity	µS/cm	1	390	336
Fluoride - ISE	mg/L	0.05	1.06	[NA]
Hardness as CaCO ₃	mg/L	1	126	123
Heterotrophic Plate Count	MPN/mL	2	<2	600
Iron (Dissolved)	mg/L	0.005	<0.005	0.029
Iron (Total)	mg/L	0.005	0.005	0.62



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 21/0800

Sample No.: Sample description: Date sampled: Time sampled:	Unit	LOR	21/0800-1 RVC Finished Water 9/06/2021	21/0800-2 RVC Raw Water 9/06/2021
Magnesium	mg/L	0.1	15.7	15.2
Manganese (Dissolved)	mg/L	0.005	<0.005	0.022
Manganese (Total)	mg/L	0.005	<0.005	0.034
pH	pH		7.6	8.0
Suspended Solids	mg/L	1	1	9
Total Coliforms	MPN/100mL	1	<1	1,553
Total Dissolved Solids by calc	mg/L	2	250	215
Total Organic Carbon*	mg/L	1	2	3
Turbidity	NTU	0.1	0.13	5.1

End of results

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

M Window
Laboratory Analyst
Approved Authoriser