



## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Sandeep Chugh  
**Sampled by:** Michael MacRae  
**Subcontract Laboratory:** Envirolab (NATA2901)  
**Subcontract Reference:** 274266

Final report

**Report no:** 21/0980  
**Date received:** 14/07/2021  
**Testing commenced:** 14/07/2021  
**Date reported:** 23/07/2021  
**No. of samples:** 2  
**Revision no:** 00

*Analysis results apply to samples as received.*

Raw and Finished Weekly

Sample No.: Sample description:	Unit	LOR	21/0980-1 RVC Finished Water 14/07/2021 12:55	21/0980-2 RVC Raw Water 14/07/2021 13:05
Date sampled:				
Time sampled:				
Alkalinity (as CaCO <sub>3</sub> )	mg/L	20	117	111
Aluminium (Dissolved)	mg/L	0.005	0.049	0.006
Aluminium (Total)	mg/L	0.005	0.057	0.40
Calcium	mg/L	0.1	22.8	22.2
Colour (Apparent)	Pt-Co	2	2	100
Colour (True)	Pt-Co	2	<2	34
<i>E.coli</i>	MPN/100mL	1	<1	411
Electrical Conductivity	µS/cm	1	408	326
Fluoride - ISE	mg/L	0.05	1.08	[NA]
Hardness as CaCO <sub>3</sub>	mg/L	1	115	112
Heterotrophic Plate Count	MPN/mL	2	<2	1,540
Iron (Dissolved)	mg/L	0.005	<0.005	0.037
Iron (Total)	mg/L	0.005	0.009	0.82



## Certificate Of Analysis

**Client:** Richmond Valley Council


**Report no:** 21/0980

Sample No.: Sample description:	Unit	LOR	21/0980-1 RVC Finished Water 14/07/2021 12:55	21/0980-2 RVC Raw Water 14/07/2021 13:05
Magnesium	mg/L	0.1	14.0	13.8
Manganese (Dissolved)	mg/L	0.005	<0.005	0.01
Manganese (Total)	mg/L	0.005	<0.005	0.027
pH	pH		7.7	7.9
Suspended Solids	mg/L	1	1	11
Total Coliforms	MPN/100mL	1	<1	3,720
Total Dissolved Solids by calc	mg/L	2	261	209
Total Organic Carbon*	mg/L	1	2	4
Turbidity	NTU	0.1	0.17	11

**End of results**

**General comments:** This report must not be reproduced except in full. This report relates to items tested as specified herein.  
 Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing  
 # NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
 LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'  
 The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

**Specific comments:**

  
 M Window  
 Laboratory Analyst  
 Approved Authoriser