



Certificate Of Analysis

Client: Richmond Valley Council

Address: Locked Bag 10
Casino NSW 2470

Contact: Sandeep Chugh

Sampled by: PM

* **Subcontract Laboratory:** NSW Health Pathology

* **Subcontract Reference:** 412827974

Sampled in accordance with RWL 2.0 to 2.05

Final report

RVC Consumer Weekly

Report no: 21/1264

Date received: 8/09/2021

Testing commenced: 8/09/2021

Date reported: 14/09/2021

No. of samples: 10

Revision no: 00

Sample No.: Sample description:	Unit	Method	LOR	21/1264/1 Woodburn Riverside Park 8/09/2021 08:12	21/1264/2 Casino Sextonville Rd 9/09/2021 12:33	21/1264/3 Casino Walker Street 9/09/2021 13:40	21/1264/4 Casino South Res 9/09/2021 12:52	21/1264/5 Coraki Memorial Park 8/09/2021 13:25	21/1264/6 Box Ridge Community 8/09/2021 13:48	21/1264/7 Broadwater Community Centre 8/09/2021 09:30	21/1264/8 Rileys Hill Community Centre 8/09/2021 09:05
pH - field	pH	APHA4500H	2	8.0	7.6	7.6	7.5	7.8	7.9	8.1	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.84	0.65	1.12	0.98	0.98	0.89	1.09	1.01
Chlorine Total - field	mg/L	APHA4500CIG	0.05	1.11	0.83	1.18	1.12	1.02	0.95	1.20	1.11
Temperature - field	Deg. C	APHA2550B	0.1	18.3	21.9	20.1	18.8	21.8	21.5	18.4	18.2
Dissolved Oxygen - field	mg/L	APHA4500OG	1	9.5	9.1	9.3	9.6	9.1	9.3	9.5	9.3
Turbidity - field	NTU	APHA2130B	0.1	0.25	0.28	0.29	0.20	0.18	0.15	0.16	0.12
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	4	4	<1	<1	2	<1	3	1



Certificate Of Analysis

Client: Richmond Valley Council


Report no: 21/1264

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	21/1264/9 Evans Head School 8/09/2021 10:35	21/1264/10 Evans Head High Zone 8/09/2021 11:06
pH - field	pH	APHA4500H	2	8.1	8.1
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.98	0.80
Chlorine Total - field	mg/L	APHA4500CIG	0.05	1.03	0.90
Temperature - field	Deg. C	APHA2550B	0.1	19.7	18.9
Dissolved Oxygen - field	mg/L	APHA4500OG	1	9.2	9.4
Turbidity - field	NTU	APHA2130B	0.1	0.10	0.13
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	1	2

End of results

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:


M Window
Laboratory Analyst
Approved Authoriser