



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Serena Tomkins
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 278970

Final report

Report no: 21/1359
Date received: 22/09/2021
Testing commenced: 22/09/2021
Date reported: 8/10/2021
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	LOR	21/1359-1 RVC Finished Water 22/09/2021 13:10	21/1359-2 RVC Raw Water 22/09/2021 13:10
Date sampled:				
Time sampled:				
Alkalinity (as CaCO ₃)	mg/L	20	127	145
Aluminium (Dissolved)	mg/L	0.005	0.040	0.039
Aluminium (Total)	mg/L	0.005	0.040	0.31
Calcium	mg/L	0.1	29.7	30.0
Colour (Apparent)	Pt-Co	2	<2	50
Colour (True)	Pt-Co	2	<2	17
<i>E. coli</i>	MPN/100mL	1	<1	14
Electrical Conductivity	µS/cm	1	438	397
Fluoride - ISE	mg/L	0.05	1.15	[NA]
Hardness as CaCO ₃	mg/L	1	147	147
Heterotrophic Plate Count	MPN/mL	2	<2	470
Iron (Dissolved)	mg/L	0.005	<0.005	0.14
Iron (Total)	mg/L	0.005	<0.005	0.34



Certificate Of Analysis

Client: Richmond Valley Council


Report no: 21/1359

Sample No.: Sample description:	Unit	LOR	21/1359-1 RVC Finished Water 22/09/2021 13:10	21/1359-2 RVC Raw Water 22/09/2021 13:10
Magnesium	mg/L	0.1	17.6	17.4
Manganese (Dissolved)	mg/L	0.005	<0.005	0.14
Manganese (Total)	mg/L	0.005	<0.005	0.14
pH	pH		7.4	7.7
Suspended Solids	mg/L	1	<1	12
Total Coliforms	MPN/100mL	1	<1	1,553
Total Dissolved Solids by calc	mg/L	2	280	254
Total Organic Carbon*	mg/L	1	3	2
Turbidity	NTU	0.1	<0.10	6.3

End of results

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
 Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
 # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
 LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
 The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:


 M Window
 Laboratory Analyst
 Approved Authoriser