



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Client
Subcontract Laboratory: Envirolab (NATA2901)
Subcontract Reference: 284032

Final report

Report no: 21/1717
Date received: 24/11/2021
Testing commenced: 24/11/2021
Date reported: 3/12/2021
No. of samples: 2
Revision no: 00

Analysis results apply to samples as received.

Raw and Finished Weekly

Sample No.: Sample description:	Unit	LOR	21/1717-1 RVC Finished Water 24/11/2021 12:30	21/1717-2 RVC Raw Water 24/11/2021 09:30
Date sampled: Time sampled:				
Alkalinity (as CaCO ₃)	mg/L	20	112	112
Aluminium (Dissolved)	mg/L	0.005	0.023	0.005
Aluminium (Total)	mg/L	0.005	0.038	0.48
Calcium	mg/L	0.1	20.4	21.3
Colour (Apparent)	Pt-Co	2	2	160
Colour (True)	Pt-Co	2	<2	41
<i>E.coli</i>	MPN/100mL	1	<1	152
Electrical Conductivity	µS/cm	1	409	304
Fluoride - ISE	mg/L	0.05	1.04	[NA]
Hardness as CaCO ₃	mg/L	1	101	107
Heterotrophic Plate Count	MPN/mL	2	<2	276
Iron (Dissolved)	mg/L	0.005	<0.005	0.048
Iron (Total)	mg/L	0.005	<0.005	0.98



Certificate Of Analysis

Client: Richmond Valley Council


Report no: 21/1717

Sample No.: Sample description:	Unit	LOR	21/1717-1 RVC Finished Water 24/11/2021 12:30	21/1717-2 RVC Raw Water 24/11/2021 09:30
Date sampled:				
Time sampled:				
Magnesium	mg/L	0.1	12.2	13.1
Manganese (Dissolved)	mg/L	0.005	<0.005	0.029
Manganese (Total)	mg/L	0.005	<0.005	0.11
pH	pH		7.4	7.7
Suspended Solids	mg/L	1	<1	26
Total Dissolved Solids by calc	mg/L	2	262	195
Total Organic Carbon*	mg/L	1	2	4
Turbidity	NTU	0.1	0.13	19

End of results

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein.
Samples tested between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:


M Window
Laboratory Analyst
Approved Authoriser