



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Chantel Cremen

Final report

Report no: 21/1911
Date received: 29/12/2021
Testing commenced: 29/12/2021
Date reported: 5/01/2022
No. of samples: 9
Revision no: 00

* **Subcontract Laboratory:**

* **Subcontract Reference:**

RVC Consumer Weekly

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	21/1911/1 Woodburn Riverside Park 29/12/2021 11:35	21/1911/2 Casino Sextonville Rd 29/12/2021 06:10	21/1911/3 Casino Walker Street 29/12/2021 10:50	21/1911/4 Coraki Memorial Park 28/12/2021 06:22	21/1911/5 Box Ridge Community 28/12/2021 07:05	21/1911/6 Broadwater Community Centre 29/12/2021 12:57	21/1911/7 Rileys Hill Community Centre 29/12/2021 12:33	21/1911/8 Evans Head School 29/12/2021 13:30
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1	<1	<1	<1	<1	<1	<1	<1
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2	<2	<2	<2	<2	<2	<2	<2
Total Coliforms	MPN/100mL	APHA9223B	1	<1	<1	<1	<1	<1	<1	<1	<1
pH - field	pH	APHA4500H	2	8.2	7.6	7.6	7.6	7.9	8.3	8.2	8.3
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.62	0.52	0.72	0.75	0.83	0.75	0.68	0.73
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.71	0.68	0.87	0.79	0.89	0.82	0.75	0.82
Temperature - field	Deg. C	APHA2550B	0.1	25.9	22.6	26.1	28.2	25.4	25.7	26.0	26.3
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.4	8.0	7.8	7.7	7.8	8.2	8.2	8.1
Turbidity - field	NTU	APHA2130B	0.1	0.10	0.32	0.49	0.16	0.12	0.11	0.15	0.10



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 21/1911

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	21/1911/9 Evans Head High Zone 29/12/2021 14:01
<i>E.coli</i>	MPN/100mL	APHA9223B	1	<1
Heterotrophic Plate Count	MPN/mL	APHA9215E	2	<2
Total Coliforms	MPN/100mL	APHA9223B	1	<1
pH - field	pH	APHA4500H	2	8.3
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.19
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.30
Temperature - field	Deg. C	APHA2550B	0.1	24.3
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.1
Turbidity - field	NTU	APHA2130B	0.1	0.12

End of results

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein.
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing
NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted.
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments:

M Window
Laboratory Analyst
Approved Authoriser