



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Chantel Cremen
*** Subcontract Laboratory:** NSW Health Pathology
*** Subcontract Reference:** 440677350

Final report

Report no: 22/0134
Date received: 25/01/2022
Testing commenced: 25/01/2022
Date reported: 31/01/2022
No. of samples: 10
Revision no: 01

Sampled in accordance with RWL 2.0 to 2.05

RVC Consumer Weekly

Sample No.: Sample description:	Unit	Method	LOR	22/0134/1 Woodburn Riverside Park 25/01/2022 08:10	22/0134/2 Casino Sextonville Rd 27/01/2022 12:31	22/0134/3 Casino Walker Street 27/01/2022 12:43	22/0134/4 Coraki Memorial Park 25/01/2022 13:37	22/0134/5 Box Ridge Community 25/01/2022 12:56	22/0134/6 Broadwater Community Centre 25/01/2022 09:19	22/0134/7 Rileys Hill Community Centre 25/01/2022 09:05	22/0134/8 Evans Head School 25/01/2022 09:57
pH - field	pH	APHA4500H	2	7.75	[NT]	7.49	7.93	7.96	8.07	7.99	8.12
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.93	[NT]	1.10	0.69	0.72	1.01	0.92	0.65
Chlorine Total - field	mg/L	APHA4500CIG	0.05	1.02	[NT]	1.24	0.80	0.75	1.21	0.95	0.73
Temperature - field	Deg. C	APHA2550B	0.1	26.2	[NT]	25.6	28.7	26.4	26.1	25.3	27.4
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.4	[NT]	7.7	7.6	7.8	8.2	8.3	7.7
Turbidity - field	NTU	APHA2130B	0.1	0.40	[NT]	0.22	0.23	0.17	0.17	0.21	0.34
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	[NT]	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	[NT]	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	7	[NT]	<1	14	9	1	25	7



Certificate Of Analysis

Client: Richmond Valley Council

Report no: 22/0134

Sample No.: Sample description: Date sampled: Time sampled:	Unit	Method	LOR	22/0134/9 Evans Head High Zone 25/01/2022 10:42	22/0134/10 Siversands Caravan Park 25/01/2022 11:12
pH - field	pH	APHA4500H	2	8.28	8.40
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.23	0.66
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.29	0.71
Temperature - field	Deg. C	APHA2550B	0.1	25.4	27.1
Dissolved Oxygen - field	mg/L	APHA4500OG	1	7.9	[NT]
Turbidity - field	NTU	APHA2130B	0.1	0.14	0.21
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	1	4

End of results

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected' The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments: This is the final report that supersedes the preliminary report issued on the 31.1.22. Unable to sample Sextonville Rd, tap thread stripped.



M Window
Laboratory Analyst
Approved Authoriser