



Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh
Sampled by: Jack O'Sullivan

Final report

Report no: 22/0379
Date received: 16/03/2022
Testing commenced: 16/03/2022
Date reported: 24/03/2022
No. of samples: 8
Revision no: 01

* **Subcontract Laboratory:** NSW Health Pathology

* **Subcontract Reference:** 442506276

RVC Consumer Weekly


Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	22/0379/1 Casino Sextonville Rd 17/03/2022 12:23	22/0379/2 Casino Showground 17/03/2022 12:40	22/0379/3 Casino Walker Street 17/03/2022 12:51	22/0379/4 Coraki Memorial Park 16/03/2022 07:42	22/0379/5 Box Ridge Community 16/03/2022 07:57	22/0379/6 Rileys Hill Community Centre 16/03/2022 09:19	22/0379/7 Evans Head School 16/03/2022 10:12	22/0379/8 Evans Head High Zone 16/03/2022 10:39
pH - field	pH	APHA4500H	2	7.66	7.57	7.55	7.94	7.96	8.27	8.43	8.48
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.43	0.68	1.02	1.11	1.14	1.46	1.15	1.04
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.50	0.76	1.21	[NT]	[NT]	1.48	1.17	[NT]
Temperature - field	Deg. C	APHA2550B	0.1	26.5	25.3	25.0	25.9	24.7	23.6	24.8	23.7
Dissolved Oxygen - field	mg/L	APHA4500OG	1	[NT]	7.8	8.0	8.0	8.1	8.4	8.3	8.2
Turbidity - field	NTU	APHA2130B	0.1	0.47	0.13	0.17	0.18	0.15	0.16	<0.10	0.11
Total Coliforms*#	MPN/100mL	PNWI01	1	<1	<1	<1	<1	<1	<1	<1	<1
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count*#	cfu/mL	PNWMF03	1	<1	<1	4	5	10	5	2	3

End of results

General comments: This report must not be reproduced except in full. This report relates only to items tested as specified herein. Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing # NATA accreditation does not cover the performance of this service. Tests marked with * are subcontracted. LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected' The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Specific comments: Unable to sample Broadwater Community Centre and Woodburn Park.


M Window
Laboratory Analyst
Approved Authoriser