



# Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470

Final report

**Report no:** 22/0432  
**Date received:** 1/04/2022  
**Testing commenced:** 1/04/2022  
2  
**Date reported:** 3/06/2022  
**No. of samples:** 3  
**Revision no:** 00

**Contact:** Sandeep Chugh  
**Sampled by:** Malcolm Window  
**\* Subcontract Laboratory:** NSW Health Pathology  
**\* Subcontract Reference:** 442506528  
*Sampled in accordance with RWL 2.0 to 2.05*

RVC Consumer Weekly

Sample No.: Sample description:	Unit	Method	LOR	22/0432/1 Casino Bruton St	22/0432/2 Casino Sheppard St	22/0432/3 Casino Walker Street
Date sampled:				1/04/2022	1/04/2022	1/04/2022
Time sampled:				11:55	12:10	11:30
pH - field	pH	APHA4500H	2	7.54	7.55	7.53
Chlorine Free - field	mg/L	APHA4500CIG	0.05	0.65	0.74	0.86
Chlorine Total - field	mg/L	APHA4500CIG	0.05	0.92	1.08	1.02
Temperature - field	Deg. C	APHA2550B	0.1	22.1	23.9	23.0
Dissolved Oxygen - field	mg/L	APHA4500OG	1	8.0	8.1	8.0
Turbidity - field	NTU	APHA2130B	0.1	0.61	0.40	0.45
Total Coliforms*#	MPN/100mL	PNWI01	1	<u>3</u>	<1	[NT]
<i>E.coli</i> *#	MPN/100mL	PNWI02	1	<1	<1	[NT]
Total Plate Count*#	cfu/mL	PNWMF03	1	90	<u>&gt;200</u>	[NT]



## Certificate Of Analysis

**Client:** Richmond Valley Council

**Report no:** 22/0432

**End of results**

**General comments:** This report must not be reproduced except in full. This report relates only to items tested as specified herein.  
Samples analysed between date received and date reported. Accredited for compliance with ISO/IEC 17025 - Testing  
# NATA accreditation does not cover the performance of this service. Tests marked with \* are subcontracted.  
LOR denotes 'Limit of Reporting' < denotes less than; > denotes greater than; ND denotes 'not detected'  
The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

**Specific comments:**

  
M Window  
Laboratory Analyst  
Approved Authoriser