

## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Sandeep Chugh

Final report

**Report no:** 22/0826  
**Date received:** 7/07/2022  
**Testing commenced:** 7/07/2022  
**Date reported:** 21/07/2022

**Sampled by:** VB

**Subcontracting Laboratory:** DPI (NATA 14173) / Envirolab (NATA 2901)

**Subcontracting Reference:** WN221145 / 300394

RVC Consumer Monthly

**No. of samples:** 3  
**Revision no:** 00

*Sampled in accordance with RWL 2.0 to 2.05*

Sample No.: Sample description:	Unit	Method	LOR	22/0826/1 Casino Walker Street 7/07/2022 14:14	22/0826/2 Casino Showground 7/07/2022 13:41	22/0826/3 Casino South Res 7/07/2022 13:56
DPI - Aluminium (Total)*	mg/L	DPI	0.001	0.050	0.064	0.12
DPI - Ammonia*	mg/L	DPI	0.02	<0.020	<0.020	<0.020
DPI - Colour True*	CU	DPI	1	<1	<1	<1
DPI - Copper (Total)*	mg/L	DPI	0.0005	0.004	0.005	0.001
DPI - Fluoride*	mg/L	DPI	0.2	1.0	0.89	1.0
DPI - Iron (Total)*	mg/L	DPI	0.005	0.009	<0.005	<0.005
DPI - Lead (Total)*	mg/L	DPI	<0.0005	<0.0005	<0.0005	<0.0005
DPI - Manganese (Total)*	mg/L	DPI	0.0005	0.002	0.0006	0.002
DPI - Nitrate*	mg/L	DPI	0.2	<0.20	<0.20	<0.20
DPI - Nitrite*	mg/L	DPI		<0.01	<0.01	<0.01
DPI - Zinc (Total)*	mg/L	DPI	0.001	0.003	0.001	0.001
Total Trihalomethanes*	µg/L	Envirolab	1	62	68	67

## Certificate Of Analysis


**Client:** Richmond Valley Council

**Report no:** 22/0826

**End of results**

**General comments:** This report must not be reproduced except in full. This report relates to items tested as specified herein. Samples analysed between date received and date reported. Tests marked with a \* are subcontracted. LOR denotes 'Limit of Reporting'  
< denotes less than; > denotes greater than; ND denotes 'not detected'

**Specific comments:**



---

M. Window  
Laboratory Analyst  
Approved Authoriser