

Certificate Of Analysis

Client: Richmond Valley Council
Address: Locked Bag 10
Casino NSW 2470
Contact: Sandeep Chugh

Final report

Report no: 22/1199
Date received: 6/10/2022
Testing commenced: 6/10/2022
Date reported: 19/10/2022

Sampled by: Rohan Das
Subcontracting Laboratory: DPI (NATA 14173) / Envirolab (NATA 2901)
Subcontracting Reference: WN221861/307724

RVC Consumer Monthly

No. of samples: 2
Revision no: 00

Sampled in accordance with RWL 2.0 to 2.05

Sample No.: Sample description:	Unit	Method	LOR	22/1199/1 Casino Walker Street 6/10/2022 13:15	22/1199/2 Casino Sextonville Rd 6/10/2022 12:50
DPI - Aluminium (Total)*	mg/L	DPI	0.001	0.011	0.023
DPI - Ammonia*	mg/L	DPI	0.02	<0.020	<0.020
DPI - Colour True*	CU	DPI	1	1	1
DPI - Copper (Total)*	mg/L	DPI	0.0005	0.005	0.004
DPI - Fluoride*	mg/L	DPI	0.2	1.1	0.73
DPI - Iron (Total)*	mg/L	DPI	0.005	0.013	<0.005
DPI - Lead (Total)*	mg/L	DPI	0.0005	<0.0005	<0.0005
DPI - Manganese (Total)*	mg/L	DPI	0.0005	0.006	0.003
DPI - Nitrate*	mg/L	DPI	0.02	0.15	0.15
DPI - Nitrite*	mg/L	DPI	0.01	<0.01	<0.01
DPI - Zinc (Total)*	mg/L	DPI	0.001	0.004	0.001
Total Trihalomethanes*	µg/L	Envirolab	1	57	99

Certificate Of Analysis


Client: Richmond Valley Council

Report no: 22/1199

End of results

General comments: This report must not be reproduced except in full. This report relates to items tested as specified herein. Samples analysed between date received and date reported. Tests marked with a * are subcontracted. LOR denotes 'Limit of Reporting'
< denotes less than; > denotes greater than; ND denotes 'not detected'

Specific comments:



M. Window
Laboratory Analyst
Approved Authoriser