

## Certificate Of Analysis

**Client:** Richmond Valley Council  
**Address:** Locked Bag 10  
Casino NSW 2470  
**Contact:** Sandeep Chugh

Final report

**Report no:** 22/1178  
**Date received:** 29/09/2022  
**Testing commenced:** 29/09/2022  
**Date reported:** 21/10/2022

**Sampled by:** Rohan Das  
**Subcontracting Laboratory:** NSW DPI (NATA 14173)  
**Subcontracting Reference:** WN221803

Weekly Fluoride & Metals

**No. of samples:** 3  
**Revision no:** 02

*Sampled in accordance with RWL 2.0 to 2.05*

Sample No.: Sample description:	Unit	Method	LOR	22/1178/1 Casino Walker Street 29/09/2022 11:50	22/1178/2 Casino Showground 29/09/2022 12:00	22/1178/3 Casino South Res 29/09/2022 12:10
DPI - Fluoride*	mg/L	DPI	0.2	0.74	0.77	0.82
DPI - Iron (Total)*	mg/L	DPI	0.005	<0.005	0.005	<0.005
DPI - Manganese (Total)*	mg/L	DPI	0.0005	0.005	0.002	0.004

### End of results

**General comments:** This report must not be reproduced except in full. This report relates to items tested as specified herein. Samples analysed between date received and date reported. Tests marked with a \* are subcontracted. LOR denotes 'Limit of Reporting'

**Specific comments:** < denotes less than; > denotes greater than; ND denotes 'not detected'  
This is the final report that supersedes the preliminary report issued on the 14.10.22  
Fluoride results redone.



V. Barnett  
Laboratory Analyst  
Approved Authoriser