

DATE OF ISSUE: 16/01/23

REPORT NO: WN230011

## Water Analysis Report

<b>REPORT NO:</b>	<b>WN230011</b>	<b>ISSUE DATE:</b>	<b>16/01/23</b>
<b>DATE SAMPLES RECEIVED:</b>	<b>3/01/23</b>	<b>PURCHASE ORDER:</b>	
<b>SAMPLES RECEIVED:</b>	<b>2</b>	<b>COMMENT:</b>	Results relate only to items tested.

<b>SUBMITTER:</b>	<b>David Cash</b>
<b>COMPANY:</b>	Richmond Valley Council
<b>ADDRESS:</b>	Locked Bag 10 CASINO NSW 2470,

<b>METHOD ID</b>	<b>ANALYSIS METHOD</b>
MB402	E.Coli and Total Coliforms in Water
MB407	Heterotrophic Plate Count
W107	EC, pH, Alkalinity & Chloride in water by autotitrator
C806	Calculations **
W112	Turbidity of water
W111	Determination of True and Apparent Colour in Water
W115	Total Suspended Solids and Fixed/Volatile Suspended Solids
C804	Hardness
M670	Elements and Metals by ICP-AES
W110	Organic Carbon in water
M671	Elements and Metals by ICP-MS

**\*\*NATA Accreditation does not cover the performances of this service.**

### LABORATORY NOTES

- Results are expressed on an 'as received' basis unless otherwise stated.
- This report should not be reproduced except in full.
- Samples will be retained for one calendar month from the date of the final report. Samples will then be discarded.
- Clients wishing to recover their samples must contact the laboratory within this period.
- This laboratory will return residual samples at client expense.

Approved for Release by:



Steven Leahy  
Chemist

Accreditation No. 14173  
Accredited for compliance with  
ISO/IEC 17025 - Testing



Wollongbar Agricultural Institute (WWAI)  
1243 Bruxner Hwy

Wollongbar NSW 2477

T: 02 6626 1103

E: wollongbar.csu@dpi.nsw.gov.au

W: www.dpi.nsw.gov.au



DATE OF ISSUE: 16/01/23

REPORT NO: WN230011

ANALYSIS RESULTS				
			1	2
Test Description	LOR	UNITS	RVC Finished Water	RVC Raw Water
Date Sampled		Date	3/01/2023	3/01/2023
Sampled By			RG	RG
Time Sampled		Time	11:15:00	9:30:00
Total coliforms in water	1	MPN/100 mL	<1	<1
E.Coli in water	1	MPN/100 mL	<1	26
Heterotrophic Plate Count_HPC	2	MPN	[NT]	[NT]
pH		pH units	7.6	7.7
TDS <sub>(calc)</sub>	6	mg/L	95	100
Electrical Conductivity	10	µS/cm	440	370
Alkalinity	14	mg/L CaCO <sub>3</sub>	140	150
Turbidity	0.07	NTU	0.097	18
Apparent colour	1	CU	<1	108
True Colour	1	CU	<1.0	8.0
Total Suspended Solids	1.0	mg/L	<1.0	21
Hardness	1.0	mg/L CaCO <sub>3</sub>	120	120
Calcium	0.03	mg/L	24	24
Magnesium	0.006	mg/L	14	14
Total Organic Carbon	0.2	mg/L	1.4	2.6
Total Aluminium	1.0	µg/L	23	640
Dissolved Aluminium	1.0	µg/L	13	6.9
Total Iron	5	µg/L	<5.0	790
Dissolved Iron	0.1	µg/L	0.54	9.3
Total Manganese	0.5	µg/L	1.5	130
Dissolved Manganese	0.1	µg/L	0.45	28