

DATE OF ISSUE: 17/03/23

REPORT NO: WN230406

Water Analysis Report

REPORT NO:	WN230406	ISSUE DATE:	17/03/23
DATE SAMPLES RECEIVED:	7/03/23	PURCHASE ORDER:	
SAMPLES RECEIVED:	2	COMMENT:	Results relate only to items tested.

SUBMITTER:	David Cash
COMPANY:	Richmond Valley Council
ADDRESS:	Locked Bag 10 CASINO NSW 2470,

METHOD ID	ANALYSIS METHOD
MB402	E.Coli and Total Coliforms in Water
MB407	Heterotrophic Plate Count
W107	EC, pH, Alkalinity & Chloride in water by autotitrator
C806	Calculations **
W112	Turbidity of water
W111	Determination of True and Apparent Colour in Water
W115	Total Suspended Solids and Fixed/Volatile Suspended Solids
W110	Organic Carbon in water
W151	Nitrite Nitrogen by FIA
W153	Oxidised Nitrogen by FIA
W161	Total Phosphorus or Total Dissolved Phosphorus in water
C804	Hardness
M670	Elements and Metals by ICP-AES
M671	Elements and Metals by ICP-MS

REPORT AUTHORISATION

Approved for Release by:



Steven Leahy
Chemist



Accreditation No. 14173
Accredited for compliance
with ISO/IEC 17025 - Testing



Wollongbar Agricultural Institute (WAAI)
1243 Bruxner Hwy
Wollongbar NSW 2477
T: 02 6626 1103
E: wollongbar.csu@dpi.nsw.gov.au
W: www.dpi.nsw.gov.au

DATE OF ISSUE: 17/03/23

REPORT NO: WN230406

ANALYSIS RESULTS				
			1	2
Test Description	LOR	UNITS	RVC Finished Water	RVC Raw Water
Date Sampled		Date	7/03/2023	7/03/2023
Sampled By			[NT]	AH
Time Sampled		Time	[NT]	10:30:00
Total coliforms in water	1	MPN/100 mL	<1	16
E.Coli in water	1	MPN/100 mL	<1	54
Heterotrophic Plate Count_HPC	2	MPN	<2	>738
pH		pH units	7.5	7.7
TDS _(calc)	6	mg/L	280	220
Electrical Conductivity	10	µS/cm	420	330
Alkalinity	14	mg/L CaCO ₃	110	120
Turbidity	0.07	NTU	0.079	24
Apparent colour	1	CU	<1	149
True Colour	1	CU	<1	12
Total Suspended Solids	1.0	mg/L	<1.0	17
Total Organic Carbon	0.2	mg/L	1.5	3.0
Dissolved Organic Carbon	0.2	mg/L	1.5	2.6
Nitrite Nitrogen	0.01	mg/L	<0.01	<0.01
Nitrate Nitrogen	0.02	mg/L	0.083	0.068
Total Phosphorus	0.03	mg/L	<0.03	0.10
Hardness	1.0	mg/L CaCO ₃	130	130
Calcium	0.03	mg/L	26	26
Magnesium	0.006	mg/L	15	15
Total Aluminium	1.0	µg/L	21	930
Dissolved Aluminium	1.0	µg/L	21	48
Total Iron	5	µg/L	<5	1,500
Dissolved Iron	0.1	µg/L	<0.10	61
Total Manganese	0.5	µg/L	1.7	110
Dissolved Manganese	0.1	µg/L	1.6	39

LABORATORY NOTES

****NATA Accreditation does not cover the performances of this service.**

- Results are expressed on an 'as received' basis unless otherwise stated.
- This report should not be reproduced except in full.
- Samples will be retained for one calendar month from the date of the final report and then discarded.
- Clients wishing to recover their samples must contact the laboratory within this period.
- Sample return is at the clients expense.
- Results for elements analysed by ICP are reported in mg/L for ICP-OES and low level analysis in ug/L for ICP-MS