

DATE OF ISSUE: 19/05/23

REPORT NO: WN230852


## Water Analysis Report

<b>REPORT NO:</b>	<b>WN230852</b>	<b>ISSUE DATE:</b>	<b>19/05/23</b>
<b>DATE SAMPLES RECEIVED:</b>	<b>9/05/23</b>	<b>PURCHASE ORDER:</b>	
<b>SAMPLES RECEIVED:</b>	<b>2</b>	<b>COMMENT:</b>	Results relate only to items tested.

<b>SUBMITTER:</b>	<b>David Cash</b>
<b>COMPANY:</b>	Richmond Valley Council
<b>ADDRESS:</b>	Locked Bag 10 CASINO NSW 2470,

<b>METHOD ID</b>	<b>ANALYSIS METHOD</b>
MB402	E.Coli and Total Coliforms in Water
MB407	Heterotrophic Plate Count
W107	EC, pH, Alkalinity & Chloride in water by autotitrator
C806	Calculations **
W112	Turbidity of water
W111	Determination of True and Apparent Colour in Water
W115	Total Suspended Solids and Fixed/Volatile Suspended Solids
C804	Hardness
M670	Elements and Metals by ICP-AES
W110	Organic Carbon in water
M671	Elements and Metals by ICP-MS

### REPORT AUTHORISATION

Approved for Release by: 

Steven Leahy  
Chemist



Accreditation No. 14173  
Accredited for compliance  
with ISO/IEC 17025 - Testing



Wollongbar Agricultural Institute (WWAI)  
1243 Bruxner Hwy  
Wollongbar NSW 2477  
T: 02 8626 1103  
E: wollongbar.csu@dpi.nsw.gov.au  
W: www.dpi.nsw.gov.au

DATE OF ISSUE: 19/05/23

REPORT NO: WN230852

ANALYSIS RESULTS				
			1	2
Test Description	LOR	UNITS	RVC Finished Water	RVC Raw Water
Date Sampled		Date	9/05/2023	9/05/2023
Sampled By			AH	AH
Time Sampled		Time	11:45:00 AM	10:50:00 AM
Total coliforms in water	1	MPN/100 mL	<1	720
E.Coli in water	1	MPN/100 mL	<1	33
Heterotrophic Plate Count_HPC	2	MPN	<2	
pH		pH units	7.5	7.7
TDS <sub>(calc)</sub>	6	mg/L	260	210
Electrical Conductivity	10	µS/cm	380	320
Alkalinity	14	mg/L CaCO <sub>3</sub>	120	130
Turbidity	0.07	NTU	0.19	13
Apparent colour	1	CU	<1.0	90
True Colour	1	CU	<1.0	7.7
Total Suspended Solids	1.0	mg/L	<1.0	15
Hardness	1.0	mg/L CaCO <sub>3</sub>	110	120
Calcium	0.03	mg/L	23	24
Magnesium	0.006	mg/L	14	14
Total Organic Carbon	0.2	mg/L	1.1	2.5
Total Aluminium	1.0	µg/L	45	580
Dissolved Aluminium	1.0	µg/L	45	44
Total Iron	5	µg/L	<5.0	970
Dissolved Iron	0.1	µg/L	0.92	31
Total Manganese	0.5	µg/L	5.5	86
Dissolved Manganese	0.1	µg/L	1.7	53

## LABORATORY NOTES

**\*\*NATA Accreditation does not cover the performances of this service.**

### RVC Raw & Finished Weekly

- Results are expressed on an 'as received' basis unless otherwise stated.
- This report should not be reproduced except in full.
- Samples will be retained for one calendar month from the date of the final report and then discarded.
- Clients wishing to recover their samples must contact the laboratory within this period.
- Sample return is at the clients expense.
- Results for elements analysed by ICP are reported in mg/L for ICP-OES and low level analysis in ug/L for ICP-MS