# Department of Primary Industries AgEnviro Labs

DATE OF ISSUE: 28/06/23

**REPORT NO:** WN231102



## Water Analysis Report

REPORT NO:	WN231102	ISSUE DATE:	28/06/23		
DATE SAMPLES RECEIVED:	13/06/23	PURCHASE ORDER:			
SAMPLES RECEIVED:	2	COMMENT:	Results relate only to items tested.		
SUBMITTER:	David Cash				
COMPANY:	Richmond Valley Council				
ADDRESS:	Locked Bag 10				
	CASINO				
	NSW 2470,				
METHOD ID	ANALYSIS METHOD				
MB402	E.Coli and Total Coliforms in Water				
MB407	Heterotrophic Plate Count				
W107	EC, pH, Alkalinity & Chloride in water by autotitrator				
C806	Calculations **				
W112	Turbidity of water				
W111	Determination of True and Apparent Colour in Water				
W115	Total Suspended Solids and Fixed/Volatile Suspended Solids				
C804	Hardness				
M670	Elements and Metals by ICP-AE	S			
W110	Organic Carbon in water				
M671	Elements and Metals by ICP-MS	S			

### REPORT AUTHORISATION

Approved for Release by:

Steven Leahy Chemist



Accreditation No. 14173 Accredited for compliance with ISO/IEC 17025 - Testing



Wollongbar Agricultural Institute (WWAI) 1243 Bruxner Hwy Wollongbar NSW 2477 T: 02 6626 1103 E: wollongbar.csu@dpi.nsw.gov.au W: www.dpi.nsw.gov.au

ANALYSIS RESULTS				
			1	2
Test Description	LOR	UNITS	RVC Finished Water	RVC Raw Water
Date Sampled		Date	13/06/2023	13/06/2023
Sampled By			AH	AH
Time Sampled		Time	12:00:00 PM	11:20:00 AM
Total coliforms in water	1	MPN/100 mL	<1	>200
E.Coli in water	1	MPN/100 mL	<1	59
Heterotrophic Plate Count_HPC	2	MPN	<2	
рН		pH units	7.6	7.9
TDS <sub>(calc)</sub>	6	mg/L	220	200
Electrical Conductivity	10	µS/cm	330	300
Alkalinity	14	mg/L CaCO <sub>3</sub>	110	120
Turbidity	0.07	NTU	1.0	16
Apparent colour	1	CU	<1.0	110
True Colour	1	CU	<1.0	8.3
Total Suspended Solids	1.0	mg/L	<1.0	16
Hardness	1.0	mg/L CaCO <sub>3</sub>	110	110
Calcium	0.03	mg/L	22	22
Magnesium	0.006	mg/L	13	13
Total Organic Carbon	0.2	mg/L	3.6	4.3
Total Aluminium	1.0	µg/L	38	620
Dissolved Aluminium	1.0	µg/L	38	50
Total Iron	5	μg/L	<5.0	1,200
Dissolved Iron	0.1	µg/L	4.0	61
Total Manganese	0.5	μg/L	1.4	70
Dissolved Manganese	0.1	μg/L	0.65	46

#### LABORATORY NOTES

### \*\*NATA Accreditation does not cover the performances of this service.

**RVC Raw & Finished Weekly** 

- Results are expressed on an 'as received' basis unless otherwise stated.
- This report should not be reproduced except in full.
  Samples will be retained for one calendar month from the date of the final report and then discarded.
- Clients wishing to recover their samples must contact the laboratory within this period.
- Sample return is at the clients expense.
  Results for elements analysed by ICP are reported in mg/L for ICP-OES and low level analysis in ug/L for ICP-MS