Department of Primary Industries AgEnviro Labs

DATE OF ISSUE: 26/09/23

REPORT NO: WN231808



Water Analysis Report

REPORT NO:	WN231808	ISSUE DATE:	26/09/23		
DATE SAMPLES RECEIVED:	12/09/23	PURCHASE ORDER:			
SAMPLES RECEIVED:	2	COMMENT:	Results relate only to items tested.		
SUBMITTER:	David Cash				
COMPANY:	Richmond Valley Council				
ADDRESS:	Locked Bag 10				
	CASINO				
	NSW 2470,				
METHOD ID	ANALYSIS METHOD				
MB402	E.Coli and Total Coliforms in Water				
MB407	Heterotrophic Plate Count				
W107	EC, pH, Alkalinity & Chloride in water by autotitrator				
C806	Calculations **				
W112	Turbidity of water				
W111	Determination of True and Apparent Colour in Water				
W115	Total Suspended Solids and Fixed/Volatile Suspended Solids				
C804	Hardness				
M670	Elements and Metals by ICP-AE	S			
W110	Organic Carbon in water				
M671	Elements and Metals by ICP-MS	3			

REPORT AUTHORISATION

Approved for Release by:

Veronica Barnett Technical Officer



Accreditation No. 14173 Accredited for compliance with ISO/IEC 17025 - Testing



Wollongbar Agricultural Institute (WWAI) 1243 Bruxner Hwy Wollongbar NSW 2477 T: 02 6626 1103 E: wollongbar.csu@dpi.nsw.gov.au W: www.dpi.nsw.gov.au

ANALYSIS RESULTS				
			1	2
Test Description	LOR	UNITS	RVC Finished Water	RVC Raw Water
Date Sampled		Date	12/09/23	12/09/23
Sampled By			AH	CC
Time Sampled		Time	11:15AM	09:45AM
Total coliforms in water	1	MPN/100 mL	<1	370
E.Coli in water	1	MPN/100 mL	<1	23
Heterotrophic Plate Count_HPC	2	MPN	<2	
рН		pH units	7.6	7.9
TDS _(calc)	6	mg/L	300	280
Electrical Conductivity	10	µS/cm	450	410
Alkalinity	14	mg/L CaCO ₃	140	150
Turbidity	0.07	NTU	0.24	9.9
Apparent colour	1	CU	3.4	51
True Colour	1	CU	<1.0	6.7
Total Suspended Solids	1.0	mg/L	<1.0	10
Hardness	1.0	mg/L CaCO ₃	140	140
Calcium	0.03	mg/L	29	29
Magnesium	0.006	mg/L	16	16
Total Organic Carbon	0.2	mg/L	1.2	2.6
Total Aluminium	0.001	mg/L	0.38	0.030
Dissolved Aluminium	0.001	mg/L	0.032	0.0028
Total Iron	0.005	mg/L	0.57	<0.0050
Dissolved Iron	0.0001	mg/L	0.0023	0.0063
Total Manganese	0.0005	mg/L	0.23	0.016
Dissolved Manganese	0.0001	mg/L	0.015	0.13

LABORATORY NOTES

**NATA Accreditation does not cover the performances of this service.

- Analysis is conducted within the date received and the date the report is finalised.
- Results are expressed on an 'as received' basis unless otherwise stated.
- This report should not be reproduced except in full.
- Samples will be retained for one calendar month from the date of the final report and then discarded.
- Clients wishing to recover their samples must contact the laboratory within this period.
- Sample return is at the clients expense.
 Results for elements analysed by ICP are reported in mg/L for ICP-OES and low level analysis in ug/L for ICP-MS