

Statement of Sediment and Erosion Control

1. All erosion and sediment control measures are to be installed prior to the commencement of any work, including cutting and filling.
2. All sediment control measures are to be constructed to prevent sediment from leaving the site or entering downstream properties, drainage lines or watercourses.
3. Disturbance of the site must be minimised.
4. A sediment control fence must be installed at the downslope perimeter of the disturbed area to prevent sediment and other debris from leaving the site. Sediment fencing is to be trenched in at least 150mm and buried with the ends turned upslope.
5. The sediment control fence must be shown on the plans submitted and labelled Sediment & Erosion Control Plan.
6. Where catchment area is more than 0.5Ha direct up slope runoff around the site, by the use of a diversion bank or channels. These devices may require measures to control erosion depending on the volume of flow anticipated.
7. Vehicular access is to be restricted to one stabilised access point which is to be constructed of 40mm crushed stone aggregate or recycled concrete 150mm deep, 2.5m wide and extend from the kerb line to the slab or building line or for at least 15m on rural allotments.
8. Stockpiles of erodible materials (sand, soil, spoil and vegetation) must be protected by a sediment fence or bund. If the stockpile area is prone to high winds or is to be there for a long time, the stockpile must be covered.
9. Stockpiled material must be stored clear of any drainage line and within the property boundary.
NOTE: stockpiles are not permitted on footpaths or roads.
10. Immediately following installation of the roof cladding, all guttering and downpipes are to be connected to the stormwater system. Inspection of the frame is not to be arranged until this is completed.
11. All erosion and sediment control measures are to be regularly maintained in good working order, at all times and inspected for adequacy following any rainfall event.
12. All trenches within the development site are to be backfilled and compacted to a level of 75mm above adjoining ground level. This may not apply on public land, consult with Council staff.
13. All disturbed areas are to be made erosion resistant by revegetation (i.e. min 70% coverage), turfing or stabilised by paving on completion of the works and prior to occupation and/or use of the building or, all necessary erosion and sediment control devices are to be left in place.

I agree to install and implement all the above measures to control erosion and sediment at the development described in the development application.

Applicant Signature: _____ Date: _____

Name (please print): _____

Privacy Advice

The personal information that Council has collected or is collecting from you is personal information for the purposes of the Privacy and Personal Information Act 1998 (PPIPA). Council will only use this information in accordance with the PPIPA.

The supply of this information by you is voluntary. However, if you cannot provide or do not wish to provide the information sought, the Council may be limited in dealing with your application/request. Council requires this personal information from you in order to process your application.

You may make application for access or amendment to your personal information held by Council. Council will consider any such application in accordance with the PPIPA. Council is to be regarded as the agency that holds the information.