

REPORT NO: WN240354

Water Analysis Report

REPORT NO: WN240354 **ISSUE DATE:** 4/03/24

DATE SAMPLES RECEIVED: 20/02/24 **PURCHASE ORDER:**
SAMPLES RECEIVED: 8 **COMMENT:** Results relate only to items tested.

SUBMITTER: David Cash
COMPANY: Richmond Valley Council
ADDRESS: Locked Bag 10
CASINO
NSW 2470,

METHOD ID	ANALYSIS METHOD
W107	EC, pH, Alkalinity & Chloride in water by autotitrator
W112	Turbidity of water
M671	Elements and Metals by ICP-MS

REPORT AUTHORISATION

Approved for Release by: 
Sarah Morison
Coordinator Analytical Services



Accreditation No. 14173
Accredited for compliance
with ISO/IEC 17025 - Testing



Wollongbar Agricultural Institute (WWAI)
1243 Bruxner Hwy
Wollongbar NSW 2477
T: 02 6828 1103
E: wollongbar.csu@dpi.nsw.gov.au
W: www.dpi.nsw.gov.au

ANALYSIS RESULTS										
			1	2	3	4	5	6	7	8
Test Description	LOR	UNITS	Woodburn Riverside Park	Rileys Hill Community Centre	Broadwater Community Centre	Evans Head School	Evans High Zone	Coraki Memorial Park	Casino Sextonville Rd	Casino Walker Street
Date Sampled		Date	20/02/24	20/02/24	20/02/24	20/02/24	20/02/24	20/02/24	20/02/24	20/02/24
Sampled By			MW	MW	MW	MW	MW	MW	MW	MW
Time Sampled		Time	7:40:00 AM	7:50 AM	8:05:00 AM	8:25 AM	8:40 AM	10:30 AM	11:20 AM	11:05 AM
Field Total Chlorine**	0.05	mg/L	0.61	0.33	0.47	0.55	0.35	0.54	0.64	1.2
Field Free Chlorine**	0.05	mg/L	0.48	0.21	0.45	0.39	0.11	0.38	0.41	0.99
Field pH**	1	pH units	7.2	7.0	7.2	7.1	7.2	7.2	7.2	7.1
Field Temperature**	1	°C	25.9	25.6	23.5	25.3	24.4	28.2	27.1	27.0
Field Turbidity**	0.07	NTU	0.23	0.21	0.24	0.25	0.26	0.18	0.74	0.24
Field Dissolved Oxygen** in %	1	%	100	100	96	100	98	100	101	100
Total Iron	0.005	mg/L							0.024	<0.0050
Total Manganese	0.0005	mg/L							0.071	0.016

LABORATORY NOTES

****NATA Accreditation does not cover the performances of this service.**

- Analysis is conducted within the date received and the date the report is finalised.
- Results are expressed on an 'as received' basis unless otherwise stated.
- This report should not be reproduced except in full.
- Samples will be retained for 10 working days from the date of the final report and then discarded.
- Clients wishing to recover their samples must contact the laboratory within this period.
- Sample return is at the clients expense.
- Results for elements analysed by ICP are reported in mg/L for ICP-OES and low level analysis in ug/L for ICP-MS