Department of Primary Industries AgEnviro Labs

DATE OF ISSUE: 20/06/24

REPORT NO: WN241015



Water Analysis Report

REPORT NO:	WN241015	ISSUE DATE:	20/06/24		
DATE SAMPLES RECEIVED:	28/05/24	PURCHASE ORDER:			
SAMPLES RECEIVED:	2	COMMENT:	Results relate only to items tested.		
SUBMITTER:	David Cash				
COMPANY:	Richmond Valley Council				
ADDRESS:	Locked Bag 10				
	CASINO				
	NSW 2470,				
METHOD ID	ANALYSIS METHOD				
MB402	E.Coli and Total Coliforms in Water				
MB407	Heterotrophic Plate Count				
W107	EC, pH, Alkalinity & Chloride in water by autotitrator				
C806	Calculations **				
W112	Turbidity of water				
W111	Determination of True and Apparent Colour in Water				
W115	Total Suspended Solids and Fixed/Volatile Suspended Solids				
C804	Hardness				
M670	Elements and Metals by ICP-AE	S			
W110	Organic Carbon in water				
M671	Elements and Metals by ICP-MS	S			

REPORT AUTHORISATION

Approved for Release by: JMA

Sarah Morison Coordinator Analytical Services



Accreditation No. 14173 Accredited for compliance with ISO/IEC 17025 - Testing



Wollongbar Agricultural Institute (WWAI) 1243 Bruxner Hwy Wollongbar NSW 2477 T: 02 6626 1103 E: wollongbar.csu@dpi.nsw.gov.au W: www.dpi.nsw.gov.au

ANALYSIS RESULTS				
			1	2
Test Description	LOR	UNITS	RVC Finished Water	RVC Raw Water
Date Sampled		Date	28/05/2024	28/05/2024
Sampled By			RG	CC
Time Sampled		Time	09:45AM	09:45AM
Total coliforms in water	1	MPN/100 mL	<1	5,200
E.Coli in water	1	MPN/100 mL	<1	180
Heterotrophic Plate Count_HPC	2	MPN	<2	
рН		pH units	8.3	8.3
TDS _(calc)	6	mg/L	230	180
Electrical Conductivity	10	µS/cm	340	280
Alkalinity	14	mg/L CaCO ₃	120	120
Turbidity	0.07	NTU	0.088	9.6
Apparent colour	1	CU	1.7	180
True Colour	1	CU	1.1	23
Total Suspended Solids	1.0	mg/L	<1.0	25
Hardness	1.0	mg/L CaCO ₃	96	98
Calcium	0.03	mg/L	19	20
Magnesium	0.006	mg/L	12	12
Total Organic Carbon	0.2	mg/L	2.0	4.0
Total Aluminium	0.001	mg/L	0.024	1.1
Dissolved Aluminium	0.001	mg/L	0.026	0.019
Total Iron	0.005	mg/L	<0.0050	1.7
Dissolved Iron	0.0001	mg/L	0.00064	0.26
Total Manganese	0.0005	mg/L	0.0015	0.060
Dissolved Manganese	0.0001	mg/L	0.0014	0.036

LABORATORY NOTES

**NATA Accreditation does not cover the performances of this service.

- Analysis is conducted within the date received and the date the report is finalised.
- Results are expressed on an 'as received' basis unless otherwise stated.
- This report should not be reproduced except in full.
 Samples will be retained for 10 working days from the date of the final report and then discarded.
- Clients wishing to recover their samples must contact the laboratory within this period.
- Sample return is at the clients expense.
 Results for elements analysed by ICP are reported in mg/L for ICP-OES and low level analysis in ug/L for ICP-MS