

## RESULTS OF WATER ANALYSIS

7 samples supplied by Richmond Valley Council on 9/07/2024. Lab Job No. R6330.  
 Samples submitted by Allison Hawthorne. Your Job: RVC Mid-Richmond Consumer Weekly  
 Locked Bag 10 CASINO NSW 2470

Parameter	Methods reference	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Sample 6	Sample 7	Sample 8
		Woodburn 09/07/24	Rileys Comm. Centre 09/07/24	Broadwater Comm. Centre 09/07/24	Evans School 09/07/24	Evans High Zone 09/07/24	Coraki Park 09/07/24	Box Ridge 09/07/24	Casino Walker St 09/07/24
	Job No.	R6330/1	R6330/2	R6330/3	R6330/4	R6330/5	R6330/6	R6330/7	R6330/8
pH	Subcontracted: NSW Health Pathology report 476011982	7.75	7.80	7.66	7.71	7.85	7.34	Not Supplied	7.15
Turbidity (NTU)	Subcontracted: NSW Health Pathology report 476011982	0.370	0.310	0.310	0.330	0.330	0.330	Not Supplied	0.270
Chlorine (Total) (mg/L)	Subcontracted: NSW Health Pathology report 476011982	1.16	1.20	1.19	0.90	0.65	0.73	Not Supplied	1.32
Chlorine (Free) (mg/L)	Subcontracted: NSW Health Pathology report 476011982	0.93	0.98	1.02	0.65	0.50	0.61	Not Supplied	1.05
Chlorine (Residual) (mg/L)	Subcontracted: NSW Health Pathology report 476011982	0.23	0.22	0.17	0.25	0.15	0.12	Not Supplied	0.27
Temperature (C)	Subcontracted: NSW Health Pathology report 476011982	18.2	16.9	16.8	17.1	16.9	17.9	Not Supplied	17.9
Total Coliforms (cfu/100 ml)	Subcontracted: NSW Health Pathology report 476011982	<1	<1	<1	<1	<1	<1	<1	<1
E.Coli (cfu/100 ml)	Subcontracted: NSW Health Pathology report 476011982	<1	<1	<1	<1	<1	<1	<1	<1
Total Plate Count (cfu/1 ml)	Subcontracted: NSW Health Pathology report 476011982	2	1	2	30	3	1	1	9

### Notes:

- 1 mg/L (milligram per litre) = 1 ppm (part per million) = 1000 µg/L (micrograms per litre) = 1000 ppb (part per billion).
- Analysis performed according to APHA (2017) 'Standard Methods for the Examination of Water & Wastewater', 23rd Edition, except where stated otherwise.
- Analysis conducted between sample arrival date and reporting date.
- \*\* NATA accreditation does not cover the performance of this service.
- ... Denotes not requested.
- This report is not to be reproduced except in full.
- All services undertaken by EAL are covered by the EAL Laboratory Services Terms and Conditions (refer scu.edu.au/eal or on request).
- Results relate only to the samples tested.
- This report was issued on 2/08/2024.

