

## RESULTS OF WATER ANALYSIS

2 samples supplied by Richmond Valley Council on 16/07/2024. Lab Job No. R6566.

Samples submitted by Water Results. Your Job: RVC Raw & Finished Weekly

Parameter	Methods reference	Sample 1	Sample 2
		RVC Finished 16/07/24	RVC Raw 16/07/24
	<i>Job No.</i>	<i>R6566/1</i>	<i>R6566/2</i>
pH	APHA 4500-H <sup>+</sup> -B	7.50	7.85
Conductivity (EC) (dS/m)	APHA 2510-B	0.339	0.297
Total Dissolved Salts (mg/L)	** Calculation using EC x 680	231	202
Total Suspended Solids (mg/L)	GFC equiv. filter - APHA 2540-D	1	19
Turbidity (NTU)	APHA 2130	0.260	29.7
True Colour (Pt-Co)	** APHA 2120	2	24
Apparent Colour (Pt-Co)	** APHA 2120	3	145
Bicarbonate (Alkalinity) (mg/L CaCO <sub>3</sub> equivalent)	** Bicarbonate Alkalinity - APHA 2320	104	112
Water Hardness (mg/L CaCO <sub>3</sub> equivalent)	** Using Ca and Mg calculation	104	108
Total Coliforms (cfu/100 ml)	APHA 9222-B	<1	6,500
E.Coli (cfu/100 ml)	ColiBlue Membrane Filtration	<1	95
Total Plate Count (cfu/1 ml)	** Inhouse	<1	..
Total Organic Carbon (mg/L)	APHA 5310-B	2.1	4.1
Aluminium (mg/L)	Total Available - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	0.030	0.830
Iron (mg/L)	Total Available - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	0.013	1.172
Manganese (mg/L)	Total Available - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	0.001	0.076
Aluminium (mg/L)	Dissolved - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	0.029	0.073
Iron (mg/L)	Dissolved - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	0.010	0.177
Manganese (mg/L)	Dissolved - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	0.000	0.002
Calcium (mg/L)	Dissolved - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	20.9	21.9
Magnesium (mg/L)	Dissolved - APHA 3125 ICPMS <sup>note 1&amp;2</sup>	12.6	13.0

### Notes:

- Total metals - samples digested with nitric acid; Total available (acid soluble/ extractable) metals - samples acidified with nitric acid to pH <2;  
Dissolved metals - samples filtered through 0.45µm cellulose acetate and then acidified with nitric acid prior to analysis
- Metals and salts analysed by Inductively Coupled Plasma - Mass Spectrometry (ICP-MS).
- 1 mg/L (milligram per litre) = 1 ppm (part per million) = 1000 µg/L (micrograms per litre) = 1000 ppb (part per billion).
- For conductivity 1 dS/m = 1 mS/cm = 1000 µS/cm.
- Analysis performed according to APHA (2017) 'Standard Methods for the Examination of Water & Wastewater', 23rd Edition, except where stated otherwise.
- Analysis conducted between sample arrival date and reporting date.
- \*\* NATA accreditation does not cover the performance of this service.
- .. Denotes not requested.
- This report is not to be reproduced except in full.
- All services undertaken by EAL are covered by the EAL Laboratory Services Terms and Conditions (refer scu.edu.au/eal or on request).
- Results relate only to the samples tested.
- This report was issued on 23/08/2024.

