

Certificate of Analysis E24-00-1576

Client:	Richmond Valley Council	Laboratory:	Environmental Analysis Laboratory
Contact:	David Cash	Contact:	EAL Customer Service Team
Address:	Locked Bag 10, CASINO, NSW 2470, Australia	Address:	PO Box 157, East Lismore NSW 2480 Australia
Telephone:	02 6660 0341	Telephone:	(02) 6620 3678
Email:	rwresults@richmondvalley.nsw.gov.au	Email:	eal@scu.edu.au

Customer reference:	RVC Casino Consumer Weekly 19.11.24	Request ID:	EAL/E24-00-1576
Number of samples:	7	Report ID:	E24-00-1576_EALP3_1
Date samples received:	02 December 2024	Issue date:	06 December 2024

Authorised by:	Alex Smith
Position:	Senior Technical Officer

Comments: EAL is a NATA accredited laboratory (14960), accredited for compliance with ISO/IEC 17025 - Testing.

Certificate of Analysis

Request ID: EAL/E24-00-1576 Report ID: E24-00-1576_EALP3_1 Issue date: 06 December 2024

				Client Sample ID:	Woodburn Park	Rileys Comm.Centre	Broadwater Comm.Centre	Evans School	Evans High Zone
				Sample Date:	19 November 2024	19 November 2024	19 November 2024	19 November 2024	19 November 2024
				EAL Sample ID:	E24-00-1576-0001	E24-00-1576-0002	E24-00-1576-0003	E24-00-1576-0004	E24-00-1576-0005
Parameter	Unit	Method Reference	LOR	---	---	---	---	---	---
pH	units	** Field analysis	---	7.09	7.41	7.47	7.22	7.45	
Turbidity	NTU	** Field analysis	<0.1	0.27	0.22	0.25	0.24	0.27	
Chlorine (Total)	mg/L	** Field analysis	<0.1	0.64	0.76	0.68	0.97	0.67	
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.42	0.70	0.54	0.57	0.21	
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.22	< 0.1	0.14	0.40	0.46	
Temperature	Celsius	** Field analysis	---	23	24	24	25	23	
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	476900606	476900606	476900606	476900606	476900606	
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1	
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1	
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	11	40	26	10	>200	

				Client Sample ID:	Coraki Park	Box Ridge
				Sample Date:	19 November 2024	19 November 2024
				EAL Sample ID:	E24-00-1576-0006	E24-00-1576-0007
Parameter	Unit	Method Reference	LOR	---	---	
pH	units	** Field analysis	---	7.30	7.30	
Turbidity	NTU	** Field analysis	<0.1	0.34	0.36	
Chlorine (Total)	mg/L	** Field analysis	<0.1	0.81	0.50	
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.52	0.38	
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.29	0.12	
Temperature	Celsius	** Field analysis	---	26	26	
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	476900606	476900606	
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	14	10	