

Water - Certificate of Analysis - E25-00-4175

Client:	Richmond Valley Council	Laboratory:	Environmental Analysis Laboratory
Contact:	Allison Hawthorne	Contact:	EAL Customer Service Team
Address:	Locked Bag 10, CASINO, NSW 2470, Australia	Address:	Military Road, East Lismore NSW 2480, Australia
Telephone:	02 6660 0341	Telephone:	(02) 6620 3678
Email:	allison.hawthorne@richmondvalley.nsw.gov.au	Email:	eal@scu.edu.au

Customer reference:	RVC Casino Consumer Weekly	Request ID:	EAL/E25-00-4175
Number of samples:	2	Report ID:	E25-00-4175_EALP1_1
Date samples received:	15 April 2025	Issue date:	24 April 2025

Authorised by:	Matt Pocock
Position:	Technical Team Leader



Comments: EAL is a NATA accredited laboratory (14960), accredited for compliance with ISO/IEC 17025 - Testing.

Certificate of Analysis

Request ID: EAL/E25-00-4175 Report ID: E25-00-4175_EALP1_1 Issue date: 24 April 2025

Client Sample ID:				Walker Street	Sextonville Rd
Sample Date:				15 April 2025	15 April 2025
Sample Time:				11.10	10.55
Sampled By:				MW	MW
EAL Sample ID:				E25-00-4175-0001	E25-00-4175-0002
Parameter	Unit	Method Reference	LOR	---	---
Chloride	mg/L	Total Available - APHA 3125 ICPMS	<10	10.3	13.1
Iron	mg/L	Total Available - APHA 3125 ICPMS	<0.005	0.007	0.006
Manganese	mg/L	Total Available - APHA 3125 ICPMS	<0.001	0.017	0.006
Free Chlorine	mg/L	** Inhouse W5	<0.02	0.020	0.33

Notes:

- ** denotes NATA accreditation does not cover the performance of this service.
- .. denotes not requested, no data/information or no guidelines available.
- All services undertaken by EAL are covered by the EAL Laboratory Services Terms and Conditions (available on request or at scu.edu.au/eal).
- Analysis conducted between sample arrival date and reporting date.
- This report is not to be reproduced except in full.
- Results only relate to the item tested.
- Analysis performed according to APHA. 2017. Standard Methods for the Examination of Water & Wastewater, 23rd Edition. Except where stated otherwise.
- Metals and salts analysed by Inductively Coupled Plasma - Mass Spectrometry (ICP-MS).
- 1:3 Nitric/HCl digest analysed in accordance with APHA 3125 ICPMS.
- mg/L = ppm