

## Certificate of Analysis E25-00-2762

Client:	Richmond Valley Council	Laboratory:	Environmental Analysis Laboratory
Contact:	Allison Hawthorne	Contact:	EAL Customer Service Team
Address:	Locked Bag 10, CASINO, NSW 2470, Australia	Address:	Military Road, East Lismore NSW 2480, Australia
Telephone:	02 6660 0341	Telephone:	(02) 6620 3678
Email:	allison.hawthorne@richmondvalley.nsw.gov.au	Email:	eal@scu.edu.au

Customer reference:	RVC Mid-Richmond Consumer Weekly	Request ID:	EAL /E25-00-2762
Number of samples:	6	Report ID:	E25-00-2762_EALP3_1
Date samples received:	14 March 2025	Issue date:	18 March 2025

Authorised by:	Alex Smith
Position:	Senior Technical Officer

Comments: EAL is a NATA accredited laboratory (14960), accredited for compliance with ISO/IEC 17025 - Testing.

Date Received: 12/03

## Certificate of Analysis

Request ID: EAL/E25-00-2762 Report ID: E25-00-2762\_EALP3\_1 Issue date: 18 March 2025

Client Sample ID:				Woodburn Park	Rileys Comm. Centre	Broadwater Comm. Centre	Evans School	Coraki Park
Sample Date:				13 March 2025	13 March 2025	13 March 2025	13 March 2025	13 March 2025
Sample Time:				8:35	8:50	9:05	9:25	9:40
Your Client:				Richmond Valley Council	Richmond Valley Council	Richmond Valley Council	Richmond Valley Council	Richmond Valley Council
EAL Sample ID:				E25-00-2762-0001	E25-00-2762-0002	E25-00-2762-0003	E25-00-2762-0004	E25-00-2762-0005
Parameter	Unit	Method Reference	LOR	---	---	---	---	---
pH	units	** Field analysis	---	7.25	7.42	7.47	7.29	7.55
Turbidity	NTU	** Field analysis	<0.1	0.39	0.50	0.62	0.29	0.34
Chlorine (Total)	mg/L	** Field analysis	<0.1	0.59	0.76	0.91	0.97	0.74
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.40	0.50	0.57	0.62	0.42
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.19	0.26	0.34	0.35	0.32
Temperature	Celsius	** Field analysis	---	25	25	24	25	25
Dissolved Oxygen	%	** Field analysis	---	95.0	99.0	100.0	99.0	96.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	478263730	478263730	478263730	478263730	478263730
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	5	3	2	1	130

Client Sample ID:				Box Ridge
Sample Date:				13 March 2025
Sample Time:				11:15
Your Client:				Richmond Valley Council
EAL Sample ID:				E25-00-2762-0006
Parameter	Unit	Method Reference	LOR	---
pH	units	** Field analysis	---	7.34
Turbidity	NTU	** Field analysis	<0.1	0.52
Chlorine (Total)	mg/L	** Field analysis	<0.1	0.83
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.55
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.28
Temperature	Celsius	** Field analysis	---	27
Dissolved Oxygen	%	** Field analysis	---	97.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	478263730
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	3