

Certificate of Analysis E25-00-2901

Client:	Richmond Valley Council	Laboratory:	Environmental Analysis Laboratory
Contact:	Allison Hawthorne	Contact:	EAL Customer Service Team
Address:	Locked Bag 10, CASINO, NSW 2470, Australia	Address:	Military Road, East Lismore NSW 2480, Australia
Telephone:	02 6660 0341	Telephone:	(02) 6620 3678
Email:	allison.hawthorne@richmondvalley.nsw.gov.au	Email:	eal@scu.edu.au

Customer reference:	RVC Mid-Richmond Consumer Weekly	Request ID:	EAL /E25-00-2901
Number of samples:	7	Report ID:	E25-00-2901_EALP3_1
Date samples received:	24 March 2025	Issue date:	02 April 2025

Authorised by:	Alex Smith
Position:	Senior Technical Officer

Comments: EAL is a NATA accredited laboratory (14960), accredited for compliance with ISO/IEC 17025 - Testing.

Certificate of Analysis

Request ID: EAL/E25-00-2901 Report ID: E25-00-2901_EALP3_1 Issue date: 02 April 2025

Client Sample ID:				Woodburn Park	Rileys Comm. Centre	Broadwater Comm. Centre	Evans School	Evans High Zone
Sample Date:				18 March 2025	18 March 2025	18 March 2025	18 March 2025	18 March 2025
Sample Time:				7:40	7:55	8:05	8:30	8:45
Sampled By:				MW	MW	MW	MW	MW
Your Client:				Richmond Valley Council	Richmond Valley Council	Richmond Valley Council	Richmond Valley Council	Richmond Valley Council
EAL Sample ID:				E25-00-2901-0001	E25-00-2901-0002	E25-00-2901-0003	E25-00-2901-0004	E25-00-2901-0005
Parameter	Unit	Method Reference	LOR	---	---	---	---	---
pH	units	** Field analysis	---	6.55	7.10	7.27	7.23	7.41
Turbidity	NTU	** Field analysis	<0.1	0.22	0.23	0.22	0.25	0.21
Chlorine (Total)	mg/L	** Field analysis	<0.1	0.64	0.64	0.55	0.89	0.64
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.41	0.41	0.44	0.40	0.61
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.23	0.23	0.11	0.49	< 0.1
Temperature	Celsius	** Field analysis	---	23	24	24	24	24
Dissolved Oxygen	%	** Field analysis	---	98.0	100.0	98.0	99.0	96.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	663417580	663417580	663417580	663417580	663417580
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1

Client Sample ID:				Coraki Park	Box Ridge
Sample Date:				18 March 2025	18 March 2025
Sample Time:				10:25	10:35
Sampled By:				MW	MW
Your Client:				Richmond Valley Council	Richmond Valley Council
EAL Sample ID:				E25-00-2901-0006	E25-00-2901-0007
Parameter	Unit	Method Reference	LOR	---	---
pH	units	** Field analysis	---	7.11	7.37
Turbidity	NTU	** Field analysis	<0.1	0.16	0.17
Chlorine (Total)	mg/L	** Field analysis	<0.1	0.87	0.82
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.52	0.72
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.35	0.10
Temperature	Celsius	** Field analysis	---	26	26
Dissolved Oxygen	%	** Field analysis	---	98.0	99.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	663417580	663417580
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1