

**No physical samples supplied - Certificate of Analysis - E25-00-6093**

Client:	Richmond Valley Council	Laboratory:	Environmental Analysis Laboratory
Contact:	Lab Results	Contact:	EAL Customer Service Team
Address:	Locked Bag 10, NSW 2470, Australia	Address:	Military Road, East Lismore NSW 2480, Australia
Telephone:	02 6660 0341	Telephone:	(02) 6620 3678
Email:	rwresults@richmondvalley.nsw.gov.au	Email:	eal@scu.edu.au

Customer reference:	RVC Mid-Richmond Consumer Weekly	Request ID:	EAL /E25-00-6093
Number of samples:	7	Report ID:	E25-00-6093_EALP3_1
Date samples received:	04 June 2025	Issue date:	23 June 2025

Authorised by:	Alex Smith
Position:	Senior Technical Officer

Comments: EAL is a NATA accredited laboratory (14960), accredited for compliance with ISO/IEC 17025 - Testing.

## Certificate of Analysis

Request ID: EAL/E25-00-6093   Report ID: E25-00-6093\_EALP3\_1   Issue date: 23 June 2025

Client Sample ID:				Woodburn Park	Rileys Comm. Centre	Broadwater Comm. Centre	Evans School	Evans High Zone
Sample Date:				27 May 2025	27 May 2025	27 May 2025	27 May 2025	27 May 2025
EAL Sample ID:				E25-00-6093-0001	E25-00-6093-0002	E25-00-6093-0003	E25-00-6093-0004	E25-00-6093-0005
Parameter	Unit	Method Reference	LOR	---	---	---	---	---
pH	units	** Field analysis	---	7.05	7.29	7.31	7.15	7.26
Turbidity	NTU	** Field analysis	<0.1	0.27	0.20	0.34	0.28	0.24
Chlorine (Total)	mg/L	** Field analysis	<0.1	1.02	1.04	1.16	1.18	0.91
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.87	0.86	1.08	0.75	0.77
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.15	0.18	< 0.1	0.43	0.14
Temperature	Celsius	** Field analysis	---	20	21	21	22	20
Dissolved Oxygen	%	** Field analysis	---	98.0	100.0	100.0	101.0	99.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	663250040	663250040	663250040	663250040	663250040
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	1	<1	6	11	1

Client Sample ID:				Coraki Park	Box Ridge
Sample Date:				27 May 2025	27 May 2025
EAL Sample ID:				E25-00-6093-0006	E25-00-6093-0007
Parameter	Unit	Method Reference	LOR	---	---
pH	units	** Field analysis	---	7.09	7.32
Turbidity	NTU	** Field analysis	<0.1	0.18	0.18
Chlorine (Total)	mg/L	** Field analysis	<0.1	1.08	1.21
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.94	1.10
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.14	0.11
Temperature	Celsius	** Field analysis	---	23	22
Dissolved Oxygen	%	** Field analysis	---	103.0	100.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	663250040	663250040
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	1	2