

Water - Certificate of Analysis - E25-00-6940

Client:	Richmond Valley Council	Laboratory:	Environmental Analysis Laboratory
Contact:	Lab Results	Contact:	EAL Customer Service Team
Address:	Locked Bag 10, NSW 2470, Australia	Address:	Military Road, East Lismore NSW 2480, Australia
Telephone:	02 6660 0341	Telephone:	(02) 6620 3678
Email:	rwresults@richmondvalley.nsw.gov.au	Email:	eal@scu.edu.au

Customer reference:	RVC Casino Consumer Weekly	Request ID:	EAL/E25-00-6940
Number of samples:	3	Report ID:	E25-00-6940_EALP3_1
Date samples received:	24 June 2025	Issue date:	07 July 2025

Authorised by:	Alex Smith
Position:	Senior Technical Officer



Comments: EAL is a NATA accredited laboratory (14960), accredited for compliance with ISO/IEC 17025 - Testing.

Certificate of Analysis

Request ID: EAL/E25-00-6940 Report ID: E25-00-6940_EALP3_1 Issue date: 07 July 2025

Client Sample ID:				Walker St	Council Depot	Bruton St
Sample Date:				24 June 2025	24 June 2025	24 June 2025
Sample Time:				11:15	12:00	11:30
Sampled By:				MW	MW	MW
Your Client:				Richmond Valley Council	Richmond Valley Council	Richmond Valley Council
EAL Sample ID:				E25-00-6940-0001	E25-00-6940-0002	E25-00-6940-0003
Parameter	Unit	Method Reference	LOR	---	---	---
pH	units	** Field analysis	---	7.15	7.07	7.07
Turbidity	NTU	** Field analysis	<0.1	0.17	0.28	0.31
Chlorine (Total)	mg/L	** Field analysis	<0.1	1.24	1.08	1.25
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.99	0.90	0.97
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.25	0.18	0.28
Temperature	Celsius	** Field analysis	---	19	20	18
Dissolved Oxygen	%	** Field analysis	---	105.0	108.0	105.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	663250941	663250941	663250941
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	<1	1	<1
Iron	mg/L	Total Available - APHA 3125 ICPMS	<0.005	< 0.005	0.006	< 0.005
Manganese	mg/L	Total Available - APHA 3125 ICPMS	<0.001	< 0.001	0.003	0.004

Notes:

- ** denotes NATA accreditation does not cover the performance of this service.
- .. denotes not requested, no data/information or no guidelines available.
- All services undertaken by EAL are covered by the EAL Laboratory Services Terms and Conditions (available on request or at scu.edu.au/eal).
- Analysis conducted between sample arrival date and reporting date.
- This report is not to be reproduced except in full.
- Results only relate to the item tested.
- Analysis performed according to APHA. 2017. Standard Methods for the Examination of Water & Wastewater, 23rd Edition. Except where stated otherwise.
- Metals and salts analysed by Inductively Coupled Plasma - Mass Spectrometry (ICP-MS).
- 1:3 Nitric/HCl digest analysed in accordance with APHA 3125 ICPMS.
- mg/L = ppm