

**No physical samples supplied - Certificate of Analysis - E25-00-7282**

Client:	Richmond Valley Council	Laboratory:	Environmental Analysis Laboratory
Contact:	Lab Results	Contact:	EAL Customer Service Team
Address:	Locked Bag 10, NSW 2470, Australia	Address:	Military Road, East Lismore NSW 2480, Australia
Telephone:	02 6660 0341	Telephone:	(02) 6620 3678
Email:	rwresults@richmondvalley.nsw.gov.au	Email:	eal@scu.edu.au

Customer reference:	RVC Mid-Richmond Consumer Weekly	Request ID:	EAL /E25-00-7282
Number of samples:	7	Report ID:	E25-00-7282_EALP3_1
Date samples received:	02 July 2025	Issue date:	07 July 2025

Authorised by:	Alex Smith
Position:	Senior Technical Officer

**Comments:** EAL is a NATA accredited laboratory (14960), accredited for compliance with ISO/IEC 17025 - Testing.

Received on 01/07/2025

## Certificate of Analysis

Request ID: EAL/E25-00-7282 Report ID: E25-00-7282\_EALP3\_1 Issue date: 07 July 2025

Client Sample ID:				Woodburn Park	Rileys Comm. Centre	Broadwater Comm. Centre	Evans School	Evans High Zone
Sample Date:				1 July 2025	1 July 2025	1 July 2025	1 July 2025	1 July 2025
Sample Time:				10:00am	10:15am	10:25am	10:55am	11.10am
Sampled By:				MW	MW	MW	MW	MW
EAL Sample ID:				E25-00-7282-0001	E25-00-7282-0002	E25-00-7282-0003	E25-00-7282-0004	E25-00-7282-0005
Parameter	Unit	Method Reference	LOR	---	---	---	---	---
pH	units	** Field analysis	---	7.20	7.30	7.15	7.35	7.33
Turbidity	NTU	** Field analysis	<0.1	0.36	0.20	0.18	0.23	0.16
Chlorine (Total)	mg/L	** Field analysis	<0.1	0.96	1.11	0.86	1.41	1.30
Chlorine (Free)	mg/L	** Field analysis	<0.1	0.85	1.08	0.68	1.17	1.15
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.11	< 0.1	0.18	0.24	0.15
Temperature	Celsius	** Field analysis	---	18	17	18	18	17
Dissolved Oxygen	%	** Field analysis	---	92.0	100.0	101.0	102.0	101.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	663251313	663251313	663251313	663251313	663251313
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1	<1	<1	<1
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	3	<1	<1	1	<1

Client Sample ID:				Coraki Park	Box Ridge
Sample Date:				1 July 2025	1 July 2025
Sample Time:				9:20am	9:35am
Sampled By:				MW	MW
EAL Sample ID:				E25-00-7282-0006	E25-00-7282-0007
Parameter	Unit	Method Reference	LOR	---	---
pH	units	** Field analysis	---	7.24	7.20
Turbidity	NTU	** Field analysis	<0.1	0.33	0.32
Chlorine (Total)	mg/L	** Field analysis	<0.1	1.29	1.24
Chlorine (Free)	mg/L	** Field analysis	<0.1	1.17	0.97
Chlorine (Residual)	mg/L	** Field analysis	<0.1	0.12	0.27
Temperature	Celsius	** Field analysis	---	19	18
Dissolved Oxygen	%	** Field analysis	---	102.0	102.0
NSW Health Pathology Report No.	---	** Subcontracted NSW Health Pathology	---	663251313	663251313
Total Coliforms	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1
E.Coli	cfu/100 mL	** Subcontracted NSW Health Pathology	<1	<1	<1
Total Plate Count	cfu/ml	** Subcontracted NSW Health Pathology	<1	<1	<1