

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED: 22-Jul-2025

COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

663251832

DATE SAMPLES RECEIVED:

22-Jul-25

TIME SAMPLES RECEIVED:

15:00

TECHNICAL OFFICER:

JB

DATE RESULTS Emailed to CLIENT:

25-Jul-25

DATE RESULTS Emailed to PHU:

25-Jul-25

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	22/07/25	9:50:00 AM	<1	<1	3	0.94	0.44	7.72	16.7	0.23
	RM04 001	Casino Sextonville Rd										
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
2	RM04 004	Casino Council Depot	22/07/25	7:45:00 AM	<1	<1	<1	0.92	0.69	7.75	16.7	0.21
	RM04 005	Casino North Reservoir										
3	RM04 006	Casino Bruton St	22/07/25	8:15:00 AM	<1	<1	<1	1.07	0.86	7.58	15.5	0.33
4	RM04 007	Casino Walker St	22/07/25	8:25:00 AM	<1	<1	<1	1.08	0.57	7.60	17.9	0.27
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	22/07/25	9:00:00 AM	<1	<1	<1	1.23	0.79	7.80	17.5	0.20
6	RM01 111	Box Ridge	22/07/25	9:20:00 AM	<1	<1	<1	1.19	1.06	7.86	16.9	0.22
7	RM01 222	Broadwater Community Centre	22/07/25	10:20:00 AM	<1	<1	<1	0.72	0.63	7.94	16.9	0.30
8	RM01 003	Rileys Hill Community Centre	22/07/25	10:00:00 AM	<1	<1	<1	1.15	0.99	7.85	16.8	0.19
9	RM01 004	Evans Head School	22/07/25	10:45:00 AM	<1	<1	<1	1.30	1.07	7.83	17.9	0.21
10	RM01 123	Evans High Zone	22/07/25	10:55:00 AM	<1	<1	2	1.24	1.03	7.86	17.1	0.28
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												