Tweed Laboratory Centre

TWEED SHIRE COUNCIL

Tweed Laboratory Centre, 46 Enterprise Avenue, Tweed Heads South, NSW, 2486
Phone: 07 5569 3103 Email: samplereception@tweed.nsw.gov.au ABN: 90 178 732 496
(All correspondence: Tweed Shire Council PO Box 816 Murwillumbah, NSW, 2484)
www.tweed.nsw.gov.au/tweedlab/

FINAL CERTIFICATE OF ANALYSIS

 Report: MICROBIOLOGY **Lims1 Report No:** **252610 / 00**

Client: Richmond Valley Council
Job Description: Raw & Finished Water - Microbiology
Client Reference: PU093817
Date of Report: 11/07/2025

Attention: Lab Results
Copy To:
Address: Locked Bag 10

CASINO
NSW 2470

All pages of this report have been checked and approved. This document may not be reproduced except in full.
Results apply to the sample(s) as submitted to the laboratory.

Sampled by: Client **Sampled:** 7/07/2025 **No of Samples:** 2
Received: 8/07/2025 **Testing Commenced:** 8/07/2025 **Testing Completed:** 10/07/2025

LIMS No.	Sample/Site Identification	Sample/Site Description	Sample Matrix
252610-1	Raw	1	Water
252610-2	Finished	2	Water

NATA WORLD RECOGNISED ACCREDITATION

Accredited for compliance with ISO/IEC 17025 - testing

Accreditation No: 12754

Dr Sally Hinton
(Scientific Officer - Phycology & Biology
shinton@tweed.nsw.gov.au

REPORT: MICROBIOLOGY

Lims1 Report No: 252610 / 00
Client: Richmond Valley Council
Job Description: Raw & Finished Water - Microbiology

REPORT COMMENTS

Additional information relevant to this report can be found in the Sample Receipt Notice and Chain of Custody.
Measurement Uncertainty available upon request.

Key:

LOR	=	Limit of reporting
^	=	NATA accreditation does not cover the performance of this service
*	=	Value is considered an estimate
NP	=	Not present
<	=	Less than
>	=	Greater than

ANALYSIS RESULTS

Sample Identification: Date Taken: Test	Method	Units	Raw 7/07/2025 11:00 AM 252610-1	Finished 7/07/2025 1:45 PM 252610-2
E. coli colilert	B12	MPN/100mL	358	---
E. coli MI Agar	B19	cfu/100mL	---	<1
Total coliforms MIAgar	B19	cfu/100mL	---	<1
Heterotrophic Plate Count	B23	cfu/mL	---	<1