

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED:

2-Sep-2025

COLLECTED BY:

M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

661195480

DATE SAMPLES RECEIVED:

02-Sep-25

TIME SAMPLES RECEIVED:

14:00

TECHNICAL OFFICER:

DO

DATE RESULTS Emailed to CLIENT:

05-Sep-25

DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	02/09/25		<1	<1	<1	1.10	0.74	7.98	17.7	0.25
	RM04 001	Casino Sextonville Rd										
2	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St	02/09/25		<1	<1	9	1.12	0.90	7.48	18.4	0.25
	RM04 004	Casino Council Depot										
3	RM04 005	Casino North Reservoir	02/09/25		<1	<1	<1	1.24	0.98	7.67	16.9	0.30
	RM04 006	Casino Bruton St										
4	RM04 007	Casino Walker St	02/09/25		<1	<1	1	1.07	0.89	7.66	18.5	0.25
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	02/09/25		<1	<1	<1	1.07	0.81	7.94	18.3	0.28
6	RM01 111	Box Ridge	02/09/25		<1	<1	2	0.99	0.79	7.95	18.6	0.21
7	RM01 222	Broadwater Community Centre	02/09/25		<1	<1	1	1.01	0.92	7.98	18.0	0.21
8	RM01 003	Rileys Hill Community Centre	02/09/25		<1	<1	1	1.30	1.07	7.99	18.1	0.25
9	RM01 004	Evans Head School	02/09/25		<1	<1	2	1.18	1.04	8.10	18.8	0.24
10	RM01 123	Evans High Zone	02/09/25		<1	<1	<1	1.23	1.15	8.13	18.3	0.21
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												