

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED: 16-Sep-2025

COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

661196340

DATE SAMPLES RECEIVED:

16-Sep-25

TIME SAMPLES RECEIVED:

14:00

TECHNICAL OFFICER:

JB

DATE RESULTS Emailed to CLIENT:

22-Sep-25

DATE RESULTS Emailed to PHU:

22-Sep-25

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	16/09/25	8:45:00 AM	3	<1	3	1.16	0.83	8.03	20.1	0.14
2	RM04 001	Casino Sextonville Rd	16/09/25	7:30:00 AM	<1	<1	13	0.96	0.75	7.74	20.1	0.26
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
	RM04 004	Casino Council Depot										
	RM04 005	Casino North Reservoir										
	RM04 006	Casino Bruton St										
3	RM04 007	Casino Walker St	16/09/25	7:15:00 AM	<1	<1	3	1.06	0.69	7.71	20.1	0.22
	RM04 008	Casino South Reservoir										
4	RM01 001	Coraki Memorial Park	16/09/25	8:10:00 AM	<1	<1	1	1.08	0.93	7.99	20.8	0.26
5	RM01 111	Box Ridge	16/09/25	8:20:00 AM	<1	<1	1	1.06	0.74	8.01	20.3	0.23
6	RM01 222	Broadwater Community Centre	16/09/25	9:15:00 AM	<1	<1	6	1.33	1.09	8.09	19.6	0.23
7	RM01 003	Rileys Hill Community Centre	16/09/25	9:00:00 AM	<1	<1	1	1.17	0.90	8.07	20.0	0.27
8	RM01 004	Evans Head School	16/09/25	9:30:00 AM	<1	<1	4	1.34	1.20	8.12	20.7	0.17
9	RM01 123	Evans High Zone	16/09/25	9:45:00 AM	<1	<1	3	1.20	0.88	8.12	20.8	0.18
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												