

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED: 19-Aug-2025

COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

661195039

DATE SAMPLES RECEIVED:

19-Aug-25

TIME SAMPLES RECEIVED:

14:00

TECHNICAL OFFICER:

JB

DATE RESULTS Emailed to CLIENT:

22-Aug-25

DATE RESULTS Emailed to PHU:

22-Aug-25

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	19/08/25	9:15:00 AM	<1	<1	<1	0.90	0.72	7.86	16.1	0.19
	RM04 001	Casino Sextonville Rd										
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
2	RM04 004	Casino Council Depot	19/08/25	7:35:00 AM	<1	<1	4	0.84	0.46	7.20	16.9	0.34
	RM04 005	Casino North Reservoir										
3	RM04 006	Casino Bruton St	19/08/25	8:05:00 AM	<1	<1	<1	1.03	0.82	7.29	15.6	0.25
4	RM04 007	Casino Walker St	19/08/25	7:45:00 AM	<1	<1	1	0.92	0.50	7.17	17.0	0.30
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	19/08/25	8:40:00 AM	<1	<1	<1	1.21	1.02	7.78	17.2	0.24
6	RM01 111	Box Ridge	19/08/25	8:50:00 AM	<1	<1	2	1.19	0.97	7.91	17.3	0.27
7	RM01 222	Broadwater Community Centre	19/08/25	9:40:00 AM	<1	<1	<1	1.16	0.99	7.98	16.4	0.21
8	RM01 003	Rileys Hill Community Centre	19/08/25	9:25:00 AM	<1	<1	<1	1.21	1.03	7.98	16.4	0.17
9	RM01 004	Evans Head School	19/08/25	10:00:00 AM	<1	<1	1	1.47	1.16	8.03	17.6	0.21
10	RM01 123	Evans High Zone	19/08/25	10:10:00 AM	<1	<1	3	1.35	1.09	8.05	16.2	0.17
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												