

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED:

23-Sep-2025

COLLECTED BY:

M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

661196517

DATE SAMPLES RECEIVED:

23-Sep-25

TIME SAMPLES RECEIVED:

13:45

TECHNICAL OFFICER:

JB

DATE RESULTS Emailed to CLIENT:

30-Sep-25

DATE RESULTS Emailed to PHU:

30-Sep-25

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries			
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature
	Site Code							1.13	0.63	8.04	19.10
1	RM01 999	Woodburn Riverside Pk	23/09/25		<1	<1	<1				
	RM04 001	Casino Sextonville Rd									
2	RM04 002	Casino Showground Res	23/09/25		<1	<1	<1	1.11	0.85	7.72	19.0
	RM04 003	Casino 15 - 17 Sheppard St									
	RM04 004	Casino Council Depot									
	RM04 005	Casino North Reservoir									
	RM04 006	Casino Bruton St									
3	RM04 007	Casino Walker St	23/09/25		<1	<1	<1	1.02	0.82	7.64	21.7
4	RM04 008	Casino South Reservoir	23/09/25		<1	<1	<1	1.23	0.83	7.70	19.2
5	RM01 001	Coraki Memorial Park	23/09/25		<1	<1	<1	1.08	0.82	7.99	20.7
6	RM01 111	Box Ridge	23/09/25		<1	<1	1	1.03	0.81	7.92	20.9
7	RM01 222	Broadwater Community Centre	23/09/25		<1	<1	<1	1.22	1.10	8.09	19.9
8	RM01 003	Rileys Hill Community Centre	23/09/25		<1	<1	<1	1.15	0.86	8.07	20.3
9	RM01 004	Evans Head School	23/09/25		<1	<1	<1	1.25	1.13	8.13	21.2
10	RM01 123	Evans High Zone	23/09/25		<1	<1	33	1.13	0.84	8.16	19.4
	RM01 006	Evans Reflections Caravan Park									
NHMRC Guideline - Health related											
NHMRC Guideline - Aesthetic											
Note: Health Dept data to be entered by Laboratory into Health Dept. database.											

Turbidity
0.40
0.17
0.14
0.20
0.16
0.24
0.23
0.31
0.25
0.23