

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED:

30-Sep-2025

COLLECTED BY:

M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

661196821

DATE SAMPLES RECEIVED:

30-Sep-25

TIME SAMPLES RECEIVED:

14:15

TECHNICAL OFFICER:

JB

DATE RESULTS Emailed to CLIENT:

07-Oct-25

DATE RESULTS Emailed to PHU:

07-Oct-25

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries			
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature
	Site Code										
1	RM01 999	Woodburn Riverside Pk	30/09/25	9:10:00 AM	<1	<1	<1	1.12	0.99	8.22	21.8
	RM04 001	Casino Sextonville Rd									
2	RM04 002	Casino Showground Res	30/09/25	7:55:00 AM	<1	<1	<1	1.02	0.76	7.67	23.9
	RM04 003	Casino 15 - 17 Sheppard St									
	RM04 004	Casino Council Depot									
	RM04 005	Casino North Reservoir									
	RM04 006	Casino Bruton St									
3	RM04 007	Casino Walker St	30/09/25	7:40:00 AM	<1	<1	<1	0.97	0.78	7.63	24.7
	RM04 008	Casino South Reservoir									
4	RM01 001	Coraki Memorial Park	30/09/25	8:30:00 AM	<1	<1	1	1.10	0.81	8.00	22.9
5	RM01 111	Box Ridge	30/09/25	8:45:00 AM	<1	<1	<1	1.10	1.00	7.97	22.7
6	RM01 222	Broadwater Community Centre	30/09/25	9:40:00 AM	<1	<1	<1	1.28	1.12	8.21	21.7
7	RM01 003	Rileys Hill Community Centre	30/09/25	9:25:00 AM	<1	<1	<1	1.25	1.14	8.19	22.3
8	RM01 004	Evans Head School	30/09/25	9:55:00 AM	<1	<1	2	1.31	1.07	8.22	22.9
9	RM01 123	Evans High Zone	30/09/25	10:10:00 AM	<1	<1	<1	1.27	1.05	8.32	23.4
	RM01 006	Evans Reflections Caravan Park									
NHMRC Guideline - Health related											
NHMRC Guideline - Aesthetic											
Note: Health Dept data to be entered by Laboratory into Health Dept. database.											

Turbidity
0.17
0.17
0.23
0.26
0.20
0.24
0.24
0.27
0.28